

G-49

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2021/GH/SW2/485

Dated: 28/10/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Shhaurya Guest House, located at Plot no-16, Pocket-B, Sector -13 Dwarka New Delhi, comprised of Basement + Ground + 3 Upper Floors was issued FSC vide Letter No F6/DFS/MS/GH/2018/SZ/306 dated 26/02/2018. The premises was re inspected by the officer concerned of this department on 10/09/2021 in the presence of Dr. D. N. Mishra (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Lodging or rooming building" Group A-1 {At 1st, 2nd & 3rd Floor(7 rooms at each floor & G.F = 2 Rooms Total 23 rooms)} with effect from 28/10/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/10/2021 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Manager, M/s Shhaurya Guest House, plot no-16, Pocket-B, Sector -13 Dwarka New Delhi.

Following fire safety directives must be adhered to:-

1. **The Exits /passage to stair shall be kept free from any obstruction/ lock and key.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement strictly shall be kept vacant as seen during inspection.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M/s Shhaurya Guest House, located at Plot no-16, Pocket-B, Sector -13 Dwarka New Delhi.
2. Type of Occupancy: Lodging or rooming;- Lodging or rooming "A-1"
3. Type of Case : Renewal (Basement + Ground + 3 Upper Floor)
4. Details of previous NOC : F6/DFS/MS/GH/2018/SZ/306 dated 26/02/2018
5. Fire Safety directives Letter No. : Old Case
6. Date of inspection :13/10/2021
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Dr. . D. N. Mishra (Manager)
9. Year of Construction : 2014
10. Applicant's letter No. : 2021081717910 Email dated 04/10/2021

G. F – Reception +2 rooms & kitchen
1 st Floor- 07 Guest Room
2 nd Floor 07 Guest Room
3 rd floor-07 Guest Room
Total 23 guest rooms

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/6		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	06 mtr	12 mtr		MR
	• Gate width	NA	NA		NA
	• Width of internal road	NA	NA		NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	2 Nos	2Nos		MR
	• Basements	2 Nos	2 Nos		MR
	b. Width of staircases				
	• Upper floors	1.5m & 1.25m	Old case		MR
	• Basements	1.5m & 1.25m	Old case		MR
	c. Protection of exits				
	• Fire check door	Required	Provided		MR
	• Pressurization	NA	NA		NA
	d. No of continuous staircase to terrace	01	Provided		MR
	e. Width Of Corridor .	1.25 mtr	1.25 mtr		MR
	f. Door Size	1m	1m		MR
3.	Compartmentation				
	• Fire check door	Required	Provided		MR
	• Sealing of electrical shafts	Required	Provided		MR
	• Fire Rating of shaft door	NA	NA		NA
	• Water Curtain	NA	NA		NA
	• Fire Dampers	NA	NA		NA

4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10Nos.	12 Nos	MR
	• Types	ABC	CO ₂ & ABC	MR
	• IS marking	Required.	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 MM	5 MM	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	CO Detectors	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01 no	01 no	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13 Pumping Arrangements			
• Ground Level			
• Discharge of main pump	NA	NA	NA
• Head of main pump	NA	NA	NA
• Number of main pumps	NA	NA	NA
• Backup pump set up	NA	NA	NA
• Backup pump head	NA	NA	NA
• Standby Pump set up	NA	NA	NA
• Standby Pump Head	NA	NA	NA
• Auto Starting Manual	NA	NA	NA
• overring	NA	NA	NA
• Pump House Access	NA	NA	NA
• Terrace level			
• Discharge of pump	100 LPM, 100 pm	Provided	VIR
• Head of the pump	17 mtr	NA	VIR
• Power supply	Required	47 at 125	VIR
• Auto starting of pump	Required	NA	VIR
14. Captive water Storage for fire fighting			
• Under ground tank capacity	NA	NA	NA
• Draw off connection	NA	NA	NA
• Fire service inlet	NA	NA	NA
• Access to tank	NA	NA	NA
• Overhead Tank capacity	10000 ltr	Provided	VIR
• Fire Signage	Required	Provided	VIR
15. Provision of Lifts			
• Pressurization of Lift Shaft	NA	NA	NA
• Pressurization of lift lobby	NA	NA	NA
• Communication in lift car	Required	Provided	VIR
• Fireman's Surrounding switch	Required	Provided	VIR
• Lift Signage	Required	Provided	VIR
• Standby power supply	Required	Provided	VIR
16. Escape Area			
• NA	NA	NA	NA
• NA	NA	NA	NA
17. Fire Fighting System			
• NA	NA	NA	NA
• NA	NA	NA	NA
• NA	NA	NA	NA
• NA	NA	NA	NA
• NA	NA	NA	NA

20. Special Fire Protection Systems for Protection of special Risks, if any:	NA	Co2 fire extinguisher provided near electric panel	MR
--	----	--	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6 DFS MS GH/2018/SZ/306 dated 26/02/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- The Exits /passage to stair shall be kept free from any obstruction/ lock and key. *as shown in the photographs placed from SL no C/33 to C/37.*

1/10
~~Signature of the Inspecting Officer~~
 Name: Udai vir Singh
 Designation : ADO (DWK)

~~DO/SW~~ *To CO Detectors & Fire check doors have been provided in Guest House bldg, Cox is recommended please.*

Kir
~~22/10~~

~~DO/SW~~

[Signature]

A DO (DWK)

bir AP letter to put up for sig ple

~~DO/SW~~

[Signature]

M.S. [Signature]

to
~~22/10/21~~