

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021/WZ/Cos/ 545

Dated: 02/11/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Dream Cosmetics, located at Plot No. M-60, Sec-5, Bawana, Industrial Area, Bawana Delhi-110039 comprised of Basement+Ground+Mezzanine+First Floor owned/occupied by M/s Dream Cosmetics was issued fire safety certificate vide Letter No. F6/DFS/MS/2018/WZ/2357 dated 17/10/2018 have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 25/10/2021 in the presence of Sh. Vijay Singh and that the building premise is fit for occupancy under "Class Industrial Building G-2(ii)" with effect from 02/11/2021 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 02/11/2021 at New Delhi

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
WEST ZONE

MLR

**Conditions for the validity of Fire Safety Certificate:**

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Copy to :-

1. M/s Dream Cosmetics, M-60, Sector-5, Bawana Industrial Area, Delhi-39.
2. Dy. Drug controller /licensing authority Govt. of NCT. Of Delhi, Drug Controller Department, F-17, Karkardooma, Delhi-110032.

INSPECTION REPORT

1. Name & address of the building: M/s Dream Cosmetics , Plot No-M-60, Sector-5 , DSIIDC  
Bawana Industrial Area, Delhi-39
2. Type of Occupancy : Industrial G-2(ii)
3. Building Comprised : **B+Gr.+Mezzanine+ First Floor.**
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/2018/WZ/2357 Dated-17/10/2018
6. Fire Safety directives letter No : F6/DFS/MS/BP/2018/4156 Dated- 04/10/2018
7. Date of inspection : 25.10.2021
8. Name of the Inspecting Officer : ADO, R.K.Sinha.
9. Name and designation of officers  
from the building side : Sh. Vijay Singh
9. Year of Construction : 2011
10. Applicant's letter No. : Diary No. 3302 Dated-08/10/2021

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	06 m	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.25 m each	1.50 m each	MR
	• Basements	1.25 m each	1.50 m each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	MR
	d. No. of continuous staircases to terrace	01	02	MR



	e. Width of Corridor	1.50 m	1.50 m	MR
	f. Door Size	1.00m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30a/c per hour	Exhaust Fan Provided	MR
	• Upper floors	12a/c per hour	Exhaust Fan Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	08 nos	10 nos	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	Required	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	Provided	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR

*Re*



	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	100 mm, 01	NA
		NA	01	NA
		NA	01	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul>			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul>	450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	10,000ltrs	MR

	Required	Provided	MR
15 Exit Signage.			
16 Provision of Lifts.			
• Pressurization of Lift Shaft	NA	NA	NA
• Pressurization of Lift lobby	NA	NA	NA
• Communication In lift Car	NA	NA	NA
• Fireman's Grounding Switch	NA	NA	NA
• Lift Signage	NA	NA	NA
17 Standby power supply	NA	Provided	NA
18 Refuge Area.			
➤ Total Area	NA	NA	NA
➤ Location	NA	NA	NA
19 Fire Control Room			
• Detector System Panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Batter backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
20 Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standard on fire prevention and fire safety required under the rules, the FSC issued vide letter no. F6/DFS/MS/2018/WZ/2357 dated 17/10/2018, is recommended for renewal of Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Dd (AD) (on leave)

Dd (AD) (WZ)

[Signature]  
11/11/2021

[Signature]  
ADO (BW)  
25/10/21

Signature of the Inspecting Officer  
Name: - Rajeev Kumar Sinha  
Designation-ADO/BW

A7 - ~~ADD~~

As Approved, F.T. letter is put up for your signature pl.

Dy. CFO (WZ)

[Signature]  
21/11/2021

[Signature]  
02/11/2021

ms cell