



C-23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 894

Dated: 29/10/2021

FIRE SAFETY CERTIFICATE

Certified that **Govt. Boys Senior Secondary School Ghitorni, New Delhi 110038 (ID-1720034)** comprised of ground plus three upper floor (01 Block) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by officer concern of this department on 07/10/2021 in the presence of Mr. Ashok Kumar (Electrical Dep.) and that the premises is fit for occupancy class "**Educational, Group-B**" (School) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 29/10/2021 at New Delhi by


(ATUL GARG)
DIRECTOR

Copy to: -

1. The Principal, Govt. Boys Senior Secondary School Ghitorni, New Delhi 110038 (ID-1720034)
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

2/6

INSPECTION REPORT

| | | | | |
|--------------|--|---|---------------------------|-----------------------|
| 1 | Name & Address of the Building | Govt. Boys Senior Secondary School Ghitorni, New Delhi 110038 (ID-1720034) | | |
| 2 | Type of Occupancy | Educational | | |
| 3 | Building Comprised of | One Block, Ground plus Three upper floor (old Block G+1 Not for use.) | | |
| 4 | Type of Case | New case | | |
| 5 | Details of Previous NOC | Nil | | |
| 6 | Fire Safety Directives Letter No | NBC Part IV / UBBL 2016 | | |
| 7 | Date of Inspection | 07/10/2021 | | |
| 8 | Name of the Inspecting Officers | Sh. Rajesh Kumar ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Mr. Ashok Kumar (Electrical Dep.) | | |
| 10 | Year of construction | 2021 | | |
| 11 | Applicant letter No. | 54(SPS School)/PWD Edu. Sub-Divn M1-1(N)/2021-22/111 Dated 27/08/2021 | | |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | NBC Part IV / UBBL 2016 | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | Required | 6 mtr | MR |
| | • Gate width | Required | 6 mtr | MR |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | Required 02 | 04 No's | MR |
| | ➤ Basement floor. | -NA- | -NA- | -NA- |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 1.5 mtr | 1.50 mtr each | MR |
| | ➤ Basement floor | -NA- | -NA- | -NA- |
| | c) Protection of exits | | | |
| | ➤ Fire check door | -NA- | -NA- | -NA- |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | -NA- | -NA- | -NA- |
| | e) Width of corridor | -NA- | NA | -NA- |
| | f) Door size | 1.2 mtr | Provided with double door | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door. | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | • Basement | 30a/c per hour | -NA- | -NA- |
| | • Upper floors | 12a/c per hour | -NA- | -NA- |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | Required | 20 Nos | MR |
| | • Types | CO ² &ABC | CO ² & ABC | MR |
| | • ISI Marking | ISI mark | Provided | MR |
| 6. | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | -NA- | -NA- | -NA- |
| | • Length of hose-reel hose. | -NA- | -NA- | -NA- |

N17

| | | | | |
|-----|--|-------------|----------|------|
| | • Nozzle Diameter | -NA- | -NA- | -NA- |
| 7 | Automatic fire detection & alarming system. | | | |
| | • Type of detectors | -NA- | -NA- | -NA- |
| | • Location of Main Panel | -NA- | -NA- | -NA- |
| | • Location of Repeater Panel | -NA- | - | -NA- |
| | • Alternate source of power | -NA- | -NA- | -NA- |
| | • Hooter's location | -NA- | -NA- | -NA- |
| 8. | MOEFA | -NA- | -NA- | -NA- |
| 9. | Public Address System | -NA- | -NA- | -NA- |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | -NA- | -NA- | -NA- |
| | • Upper floors | -NA- | -NA- | -NA- |
| | • Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | • Size of Riser/Down-comer | Required | 100 mm | MR |
| | • Number of Hydrant per floor | Required | 02 | MR |
| | • Hose box. | Required | 02 | MR |
| 12. | Yard Hydrants. | | | |
| | • Total number of hydrants. | -NA- | -NA- | -NA- |
| | • Hose box. | -NA- | -NA- | -NA- |
| 13. | Pumping arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main pump. | -NA- | -NA- | -NA- |
| | ➤ Head of main pump. | -NA- | -NA- | -NA- |
| | ➤ Number of main pumps. | -NA- | -NA- | -NA- |
| | ➤ Jockey Pump output. | -NA- | -NA- | -NA- |
| | ➤ Jockey Pump head. | -NA- | -NA- | -NA- |
| | ➤ Standby Pump output | -NA- | -NA- | -NA- |
| | ➤ Standby Pump head. | -NA- | -NA- | -NA- |
| | ➤ Auto Starting / Manual Stopping | -NA- | -NA- | -NA- |
| | ➤ Pump house access. | -NA- | -NA- | -NA- |
| | • Terrace Level | | | |
| | ➤ Discharge of pump. | 2 x 450 LPM | Provided | MR |
| | ➤ Head of pump. | 40 | Provided | MR |
| | ➤ Power supply. | Required | Provided | MR |
| | ➤ Auto starting of pump. | Required | Provided | MR |
| 14. | Captive water storage for fire fighting. | | | |
| | • Underground tank capacity. | -NA- | -NA- | -NA- |
| | ➤ Draw-off connection. | -NA- | -NA- | -NA- |
| | ➤ Fire Service Inlet. | -NA- | -NA- | -NA- |
| | ➤ Access to tank. | -NA- | -NA- | -NA- |
| | • Overhead tank capacity. | 10,000 ltr | Provided | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of lift shaft | -NA- | -NA- | -NA- |
| | • Pressurization of lift lobby. | -NA- | -NA- | -NA- |
| | • Communication in lift car. | -NA- | -NA- | -NA- |
| | • Fireman's switch. | -NA- | -NA- | -NA- |
| | • Lift signage. | -NA- | -NA- | -NA- |
| 17. | Standby Power Supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | • Total area | -NA- | -NA- | -NA- |

21
tu

M/8

| | | | | |
|-----|---|------|------|------|
| | • Location | -NA- | -NA- | -NA- |
| 19. | Fire Control Room. | | | |
| | • Detector system panel. | -NA- | -NA- | -NA- |
| | • Flow switch panel. | -NA- | -NA- | -NA- |
| | • PA system panel. | -NA- | -NA- | -NA- |
| | • Battery backup. | -NA- | -NA- | -NA- |
| | • Building floor plan. | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | -NA- | -NA- | -NA- |

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.


Signature
21/10/2024

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

~~DO (SD)~~
Signature
11/10/24

Signature
22/10

Signature
25/10



Signature
26/10/2024

As appressed, f.t. letter is put up for your signature

Signature
28/10/2024

Signature
28/10/2024