

C-20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.F6 /DFS/MS/EH/NDZ/2021/ 307

Dated: 27/10/21

FIRE SAFETY CERTIFICATE

Certified that the restaurant in the name and style of **Hari Sharnam Bhojanalaya** is running at 1st floor of property no. 1490 - 91, near Ritz Cinema, Kashmere Gate, Delhi (building is comprised of ground + 02 upper floors) is owned/ occupied by Shri Suresh Chandra. The premises was inspected by a team of officers from this department on 18.10.2021 in presence of Mr. Vijay Kumar Mishra (Manager) and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Group D (**Assembly Building, Restaurant**) with effect from 27/10/21..... for a period for three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules 2010 printed below.

Issued on ...27/10/21..... at New Delhi by


(Atul Garg)
Director

Tel: 011-23414000.

Copy to:

1. The Joint Commissioner of Police (Licensing), 1st floor, P. S. Defence Colony, New Delhi w. r. to application no. 2021082519040 dated 26.08.2021.
2. The Manager, Hari Sharnam Bhojanalaya located at 1st floor of property no. 1490 - 91, Near Ritz Cinema, Kashmere Gate, Delhi - 06.

Conditions for validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall only be used as per BBL 1983.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Dept. and approval shall be obtained there to before occupancy of the same.
10. This Fire Safety Certificate is valid for 1st floor only (floor occupied by eating house).

N/7
INSPECTION REPORT

1.	Name and address of the building:	1490-91, Hari Sharnam Bhojanalaya, near Ritz Cinema, Kashmere Gate, Delhi - 06.
2.	Type of occupancy with details of floors:	Ground + 02 upper floors Restaurant running at 1 st floor only.
3.	Type of case:	Fresh Case
4.	Details of previous FSC:	Nil.
5.	Fire safety directives no.:	Nil.
6.	Date of inspection:	18.10.2021.
7.	Name of the inspecting officer:	ADO (SPM) Rajesh Kumar Shukla.
8.	Name and designation of the officer from the building side:	Shri Vijay Kumar Mishra (Manager)
9.	Year of construction:	2017(year of change of occupancy)
10.	Reference letter no.:	Online ID no. 2021082519040 dated 26.08.2021

S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements (As per NBC IV & UBBL 2016)	Provide at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	06 mtrs.	09 mtrs.	MR
	B Gate width	NA	NA	NA
	C Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits:			
	A No. of Staircase:			
	a) Upper floor	2 nos.	2 nos.	MR
	b) Basements	NA	NA	NA
	B Width of the Staircase:			
	a) Upper floors	1.5 mtrs (each)	1.5 mtrs (each)	MR
	b) Basements	NA	NA	NA
	C Protection of Exits			
	a) Fire Check Door	NA	NA	NA
	b) Pressurization	NA	NA	NA
	D No. of continuous staircase to terrace	01 no.	01 no.	MR
	E Width of the corridor	NA	NA	NA
	F Door size	1.5 mtrs	1.5 mtrs	MR
3	Compartmentation:			
	A Fire check doors	NA	NA	NA
	B Sealing of horizontal & vertical opening	NA	NA	NA
	C Fire rating of shaft doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke management System:			
	A Basements	NA	NA	NA
	B Upper floors	Natural/ Mechanical	Natural + exhaust fans	MR
5	Fire extinguishers:			
	A Total numbers	04 nos.	06 nos.	MR
	B Types	ABC + CO ₂	ABC + CO ₂	MR
	C ISI marking	ISI marked	ISI marked	MR

6	First Aid Hose reel:					
	A	Total no. at each floor	01 no.	01 no.	MR	
	B	Length of hose reel	30 m	30 m	MR	
	C	Nozzle diameter	5 mm	5 mm	MR	
7	Automatic Fire Detection and Alarm System (ADAS):					
	A	Type of detectors	NA	Provided	NA	
	B	Location of main panel	NA	Provided at 1 st floor	NA	
	C	Location of repeater panel	NA	NA	NA	
	D	Alternate power source	NA	NA	NA	
	E	Hooter's location	NA	At 1 st floor	NA	
8	MOEFA:		Required	Provided	MR	
9	Public Address System:		NA	NA	NA	
10	Automatic Sprinkler System:					
	A	Basement	NA	NA	NA	
	B	Ground & upper floor	NA	NA	NA	
	C	Sprinklers above false ceiling	NA	NA	NA	
11	Internal Hydrants:					
	A	Size of down comer	100 mm	100 mm	MR	
	B	No. of hydrants per floor	1 no.	1 no.	MR	
	C	Hose box per floor	1 no.	1 no.	MR	
12	Yard Hydrants:					
	A	Total no. of hydrants	NA	NA	NA	
	B	Hose box	NA	NA	NA	
13	Pumping arrangements:					
	A	Ground Level				
		a)	Discharge & head of main pump	NA	NA	NA
		b)	Number of main pump	NA	NA	NA
		c)	Discharge & head of jockey pump	NA	NA	NA
		d)	Discharge & head of standby pump	NA	NA	NA
		e)	Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level				
		a)	Discharge of terrace pump	450 LPM	450 LPM	MR
		b)	Head of terrace pump	40m	40m	MR
		c)	Alternate power supply	Required	Provided	MR
		d)	Auto starting of pump	Required	Provided	MR
	14	Captive Water Storage for Fire Fighting:				
A		Underground tank capacity	NA	NA	NA	
B		Draw off connection	NA	NA	NA	
C		Fire service inlet	NA	NA	NA	
E		Access to tank	NA	NA	NA	
D		Overhead tank capacity	20,000 Liters	Provided	MR	
15	Exit Signage:		Required	Provided	MR	
16	Provision of lift:					
	A	Pressurization of lift shaft	NA	NA	NA	
	B	Pressurization of lift lobby	NA	NA	NA	
	C	Communication in lift car	NA	NA	NA	
	D	Fireman switch	NA	NA	NA	
	E	Lift signage	NA	NA	NA	
17	Standby Power Supply:		Required	Provided	MR	


2/9

18	Refuge Area:			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room:			
A	Fire detection system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any			
A	Special Fire Protection system for Protection of Special Risk, if any:			NA

Meeting requirement (MR), Not meeting requirement (NMR), Not applicable (NA) Provide but not functional (PNF).

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under Rule 33 of Delhi Fire Service (DFS) Rules 2010, issuance of Fire Safety Certificate to the restaurant is recommended under Rule 35 of DFS Rules 2010.

 18/12/21

Signature of the Inspecting Officer

Name: Rajinder Atwal

Designation DO (CD) - A

 18/12/21

Signature of the Inspecting Officer

Name: Rajesh Kumar Shukla


Designation ADO (SPM)

~~Dy.CFO (NDZ)~~

 22/10/21

~~CF (H.O.) - 01/08~~

~~Director~~



FFP4

1. Avoid such mistakes

2. Be careful in future.



 25/10/21

Kbody see A also



DO (CD) + ADO (SPM)

1. noted, will take care in future. Error regretted.

2. Fresh notice for N/A is placed on file (notice side) to be uploaded along with FSC Contd..