

C 38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6 DFS/MS/School/2021/SZ/ 898

Dated: 29/10/2021

FIRE SAFETY CERTIFICATE

Certified that **Sarvodaya Kanya Vidyalaya, Tughlakabad village, New Delhi- 110044, (ID 1925040)** comprised of Two Blocks, Ground plus One upper floors & Ten Blocks each ground floor in tin sheds and Two Blocks each Ground plus three upper floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/46 Dt. 05/10/2018. The said premises was re-inspected by officer concerned of this department on 18/10/2021 in presence of Dr. Amita Puri (Vice-Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 29/10/2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 29/10 2021 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya, Tughlakabad village, New Delhi- 110044 (ID 1925040)
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

M/17

INSPECTION REPORT

1	Name & Address of the Building	Sarvodaya Kanya Vidyalaya, Tughlakabad village, New Delhi ID - 1925040		
2	Type of Occupancy	Educational Building, Group - B (School)		
3	Building Comprised of	Old Blocks- Ground + One Upper Floor (02 Blocks) & GF only Ten Block New Block- Ground + Three upper floors (02 Block)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/46 Dt. 05/01/2018		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	18/10/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Virender Kumar (Estate Manger)		
10	Year of construction	1990 & 2016		
11	Applicant letter No.	Gmail Dated 27/09/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC /BBL requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required	6 mtr	MR
		-NA-	4.5 mtr	-NA-
		-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	old, block - 1 No each New, Block - 02 & 03 No's	old, block - 1 No each New, Block - 02 & 03 No's	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50 m / 0.75 m 1.50 mtr	Old block - 1.5 m each New Block - 1.80m each	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02 No in new block	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	40 No's ABC / co2 ISI mark	40 No's ABC- 16 , Co2 - 14 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. 	02 No's each Block	Provided in each block	MR

M18

	<ul style="list-style-type: none"> Length of hose-reel hose. Nozzle Diameter 	30 m 5 mm	30 m 5 mm	MR MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA- -NA-	-NA- -NA-	-NA- -NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 450 LPM each 40 m each Required Required	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 450 LPM each 40 m each Provided Provided	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- MR MR MR MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA- -NA- -NA- -NA- 10,000 ltrs each	-NA- -NA- -NA- -NA- Provided	-NA- -NA- -NA- -NA- MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA- -NA-	-NA- -NA-	-NA- -NA-
19.	Fire Control Room.			

N/19

	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 52 dated 03/02/2021

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/46 Dt. 05/01/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Sh
21/10/2021

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

~~DO (SB)~~

Sh
21/10/21

DeFO (SZ)

[Signature]
22/10

ADO (BCP)

As approved, f.t. letter is put up for your signature pl

Sh
26/10

DeFO (SZ)
[Signature]

M.S. cell