

C-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/School/WZ/2021/ 922

Dated: 05/11/21

FIRE SAFETY CERTIFICATE

Certified that **B.R. International Secondary Public School** located at **RZ/E-250, Nihal Vihar, Nangloi, New Delhi- 110041**, comprised of basement, ground plus two upper floors, was granted Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2018/2006 dated 31.08.2018. The school building was re-inspected by the officer concerned of this department on 25.10.2021 in the presence of Sh. HPS Bakshi, manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule- 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and that the building/premises is fit for occupancy class "Educational" with effect from 05/11/21 for a period of three years, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules- 2010, printed overleaf.

Issued on 05/11/21 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

05/11/21
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Principal,
B.R. International Secondary Public School,
RZ/E-250, Nihal Vihar, Nangloi, New Delhi- 41.
2. The Directorate of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement floor shall be used as per building bye-laws.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : B.R. International Secondary Public School, RZ/E-250, Nihal Vihar, Nangloi, New Delhi- 110041.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/2006 dated 31/08/2018
5. Fire Safety directives letter No : N/A
6. Date of inspection : 25.10.2021
7. Name of the Inspecting Officers : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of officers
from the building side : Sh. HPS Bakshi, Manager
9. Year of Construction : 2015
10. Applicant's letter No. : Nil dated nil.

B.R. International Secondary Public School is comprised of basement, ground plus two upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	01	03	MR
	• Basements	01	03	MR
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5, 1.35 mts	1.74, 1.54, 1.05 mts	MR
	• Basements	1.5, 1.35 mts	1.74, 1.54, 1.05 mts	MR
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 No.	03 Nos.	MR
	g. Width of Corridor	1.5 mts	1.5 mts	MR
	h. Door Size	1.0 mt	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	N/A	N/A

5	Fire Extinguishers	08 nos.	Provided	MR
	• Total numbers	ABC, CO ₂ type	Provided	MR
	• Types	ISI marked	Provided	MR
	• IS marking			
6	First-Aid Hose Reels.	02	02	MR
	• Total numbers on each floor			
	• Length of hose reel hose	30 mts	30 mts	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM x 02	450 LPM x 02	MR
	➤ Head of the pump	40 mts each	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR

MR
MR

Provision of Lifts.

Not Applicable

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2018/2006 dated 31/08/2018, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DFA is put up for approval & signature please.

[Handwritten signature]
30/10/21

Signature of the Inspecting Officer
(Aman Kumar Lathar)
Asst. Divisional Officer (JWP)

D.O. (West Division)

166
30/8/21

[Handwritten signature]
30/10/2021

DFA (W2)

[Handwritten signature]
11/11/2021

[Handwritten signature]

F.I. letter is put-up for your signature lot.

DFA (W2)

[Handwritten signature]
02/11/21
Asst. (JWP)

Mscell

[Handwritten signature]
31/11/2021