

C-16

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 329

Dated: 09/11/2021

FIRE SAFETY CERTIFICATE

Certified that the buliding M/s Kadimi's Food Pvt Ltd. Located at 2nd floor Plot No 7, Sector - 11, Pkt - IV, Dwarka, New Delhi - 110075, is running at 2nd floor in a building comprised of Ground + 03 Upper Floors was issued FSC vide Letter no. F6/DFS/MS/EH/2018/SZ/2744 Dated 24/12/18, The premises was re inspected by the officers concerned of this department on 30-09-2021 in the presence of Sh. Manish Jain and found that the said building have deemed complied with the fire prevention and fire safety requirements in- accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" **Group D (Restaurant at 2nd Floor Only)** with effect from 09/11/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on09/11/21 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Dy Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.
2. The Add. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
3. M/s Kadimi's Food Pvt Ltd. Located at 2nd floor Plot No 7, Sector - 11, Pkt - I V, Dwarka, New Delhi - 110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s Kadimi's Food Pvt Ltd. Located at 2nd floor, Plot No- 7, Sector – 11, Pkt – IV, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Assembly "D"(Restaurant is running at 2nd Floor in a building comprised of Ground + Three Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/EH/2018/SZ/2744 Dated 24/12/18
5. Fire Safety directives Letter No. : UBBL / NBC Requirements
6. Date of inspection : 30- 09 -2021
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Manish Jain
9. Year of Construction : Before 2009
10. Applicant's letter No. : 2021081217612 dated 20-09-2021

Sr. No	Minimum standards on fire prevention and fire safety U/R 33	As per N/3	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 mtr	Provided	MR
		4.5 m	Direct accessible from road	MR
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	01 nos.	01 nos	MR
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	1.25 m	1.25 m (Including railing)	MR(Old Case)
		NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
		NA	NA	NA
	d. No of continuous staircase to terrace	Required	01	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	02 mtr	1.25 m & 1mtr (Including door frame)	MR(Old Case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 Nos. ABC or CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 Nos	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	Smoke	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Required in restaurant area Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		01	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm, 180 lpm	Provided	MR
		30 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	50, 000 liters	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 Fire Extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2018/SZ/2744 Dated 24/12/18 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

1. M/s Kadimi's Food Pvt Ltd. Located at 2nd floor, Plot No- 7, Sector – 11, Pkt – IV, Dwarka, New Delhi – 110075.
2. As per letter/ plan submitted by the applicant the area of the restaurant is 204.38 m²
3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 114 (204.38/1.8=113.54 say 114) for whole restaurant.
4. The total seating capacity comes out be 114.

Signature of the Inspecting Officer
 Name
 Designation

(Signature)
 21/10/21
 Adar Vir Singh
 AOP/DWK

(Signature)
 01/11/2021
 Dy cfo (S2)
 2/11

AOP/DWK