

C/27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F6/DFS/MS/School/2021/SZ/ 932

Dated: 12/11/2021

FIRE SAFETY CERTIFICATE

Certified that the **St. Paul's School** (Delhi Orthodox Syrian Church Society) located at Phase-VI, H-Block, Aya Nagar, New Delhi-110047, comprised of 02 interconnected Blocks each Ground plus two upper floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/2470 Dated 02/11/2018. The said premises was re-inspected by officer concerned of this department on 28/10/2021 in presence of Mr. Thomas P.T (Admin) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 12/11/2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 12/11/2021 at New Delhi by



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER

Copy to: -

1. The Principal, St. Paul's School (Delhi Orthodox Syrian Church Society), H-Block, Phase-VI, Aya Nagar, New Delhi-110047.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	St. Paul's School at Phase-VI, H-Block, Aya Nagar, New Delhi-110047 (Delhi Orthodox Syrian Church Society)		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Two interconnected blocks each G+2 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/2470 Dt. 02/11/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	28.10.2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Thomas P.T (Admin)		
10	Year of construction	2008 & 2016		
11	Applicant letter No.	Gmail dated 26-09-2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL / NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	9 mtr	MR
	• Gate width	Required	4 mtr	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	➤ Upper floors.	2 Nos	3 Nos	MR
	➤ Basement floor.	NA	NA	NA
	b. Width of Staircase			
	➤ Upper floors	1.5 mtr.	1.50m, 1.20m & 1.20m	MR
	➤ Basement floor	NA	NA	NA
	c. Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	Required	Two	MR
	e. Width of corridor	1.5 mtr	1.5 mtr	MR
	f. Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	18 Nos	Provided	MR
	• Types	ABC / Co2	ABC- 18	MR
	• ISI Marking	Required	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 No	02 Nos	MR
	• Length of hose-reel hose.	30 mtr	provided	MR
	• Nozzle Diameter	5 mm	provided	MR

St. Paul's School at Aya Nagar, Phase-VI, H-Block, New Delhi-110047

7	Automatic fire detection & alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	NA	NA	NA
	• Number of Hydrant per floor	NA	NA	NA
	• Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	A. Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting / Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	B. Terrace Level			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	NA	NA	NA
	➤ Draw-off connection.	NA	NA	NA
	➤ Fire Service Inlet.	NA	NA	NA
	➤ Access to tank.	NA	NA	NA
	• Overhead tank capacity.	10,000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17.	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

