

925

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/WZ/2021/333

Dated: 11/11/2021

FIRE SAFETY CERTIFICATE

Certified that the **M/s Dhaba Restaurant** located at A5, Ground Floor, Vishal Enclave, Rajori Garden, New Delhi-110027 of a Building comprised of Ground + Two Upper Floors, Owned/Occupied by M/s. A Unit of Hotel Mugal Palace, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 27/10/2021 in the presence of Sh. Bhupender Singh Narang and found that the said building is fit for occupancy class "Assembly" (Group D) (**Ground Floor Only**) with effect from 11/11/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions Mentioned Below.

Issued on 11/11/2021 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Owner/occupier Dhaba Restaurant (A Unit of Hotel Mugal Palace) located at A5, First floor, Vishal Enclave, Rajori Garden, New Delhi-110027 (**Reference: - ID No. 2019122701132 dated: - 15/04/2021**)
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (adlcp.lic-dl@nic.in).
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhowestzone@gmail.com)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. This NOC is valid for Ground floor only.

P/b
INSPECTION REPORT

1. Name & address of the building : Dhaba Restaurant (A Unit of Hotel Mugal Palace) located at A5, First floor, Vishal Enclave, Rajori Garden, New Delhi-110027.
2. Type of Occupancy : Class D (Assembly)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 27/10/2021
7. Name of the Inspecting Officers : Sarabjeet Singh (ADO MN)
8. Name and designation of officers from the building side : Sh. Bhupender Singh Narang
9. Year of Construction : 1980 (As per MHA portal)
10. Applicant's letter No. : Online application No. 2019122701132 Dated-15/04/2021

* The Said Restaurant is running at Ground Floor in a building comprised at Ground + Two upper Floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC/ Requirement/As per pre.Ins.Rep dt.-11/05/2018	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mts	Provided	MR
		4.5 mts	On Main Road	MR
		NR	NR	NR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA (G.F.)	NA	NA
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA (G.F.)	NA	NA
		NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
		NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1.5 mts each	provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA
		Required	Provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types 	10	Provided	MR
		CO ₂ , ABC type	Provided	MR

42

		ISI marked	Provided	MR
	• IS marking			
6	First-Aid Hose Reels.			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NR	Provided	--
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	30 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NR	NR	NR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR

SA

2

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NR	NR	NR
	➤ Location	NR	NR	NR
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NR	NR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

291/ADD/MN
08/11/2021

7
Dohusht

[Signature]
01/11/2021

Signature of the Inspecting Officer
(Sarabjeet Singh)
Asst. Divisional Officer (MN)

281
1/11/2021

[Signature]
01/11/2021


DeFO (W2)

[Signature]
1/11/2021

[Signature]

[Signature]

[Signature]



[Signature]
5/11/2021

uploaded
11/11/2021

[Signature]