

C-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/EH/2021/SZ/ 336

Dated: 16/11/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s KFC Restaurant running at ground floor only a building comprised of ground plus two upper floors located at shop no. 167 B, G.F. opp. pillar no. 672, Main Road Uttam Nagar, New Delhi-110059, owned/occupied by A unit of sapphire foods India Ltd. have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 28/10/2021 in the presence of Sh. Md. Jabir and found that the building is fit for occupancy class D "Assembly Building" (Restaurant) with effect from 16/11/2021 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf. This NOC is valid only for ground floor.

Issued on ...16/11/2021 New Delhi by.


(Atul Garg)
Director

Delhi Fire Service

slc

To,

M/s KFC Restaurant (A unit of sapphire food India Ltd.)

Shop no. 167 B, G.F. Opp. Pillar no. 672, Main road Uttam Nagar, New Delhi-110059.

Copy To: -

The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station, Defence Colony,
New Delhi.

Following fire safety directives must be adhered to:-

- The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- All the means of escape shall be kept free of all the type of obstruction all the time.
- All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- The clarification with regards electrical installation, ventilation, structure stability set back areas occupancy and constructional deviation in building etc. may be got verified from the authorities concerned,
- This fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any,
- The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

M1

1. Name & address of the building : M/s KFC Restaurant (A unit of sapphire foods India Ltd),
Shop no. 167 B G.F. Opp. Pillar no. 672, Main Road
Uttam Nagar, New Delhi-110059.
2. Building is comprised of : G+2 (Eating house running at Ground floor only)
3. Type of Occupancy : Assembly (Eating)
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 28/10/2021
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer
from the building side : Md. Jabir (Manager)
10. Year of Construction : 2020
11. Applicant's letter No : ID No. 2021100623551 Dated 08/10/21

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 06 mtr. N/A N/A 	<ul style="list-style-type: none"> 06 mtr. N/A N/A 	<ul style="list-style-type: none"> MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> Required N/A 	<ul style="list-style-type: none"> Provided N/A 	<ul style="list-style-type: none"> MR N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 & 1.5 m	2 M & 2x1.5 m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	<ul style="list-style-type: none"> Required N/A N/A N/A N/A 	<ul style="list-style-type: none"> Provided N/A N/A N/A N/A 	<ul style="list-style-type: none"> MR N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 04 nos. ABC /CO₂ ISI marked 	<ul style="list-style-type: none"> 04nos. Provided Provided 	<ul style="list-style-type: none"> MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 No.	Provided	MR
	• Length of hose reel hose	30 mtr.	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Smoke	Provided	MR
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	Basement	N/A	N/A	N/A
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	Provided	MR
	• Number of hydrants per floor	01 No.	Provided	MR
	• Hose box	01 No.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 Lpm.	Provided	MR
	• Head of the pump	40 M	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	20,000 Ltrs.	20,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift Shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.
 Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer
 Name :-R.K.Yadav
 Designation :-ADO(JKP)

R.K. Yadav
 01/11/2021

DO (South West)

R.K. Yadav
 03/11/2021

By cfo *[Signature]*

[Signature]
 8/11

CFO

[Signature]
 9/11

[Signature]
 9/11/21

HTPS

DO/SW

