

69

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

NEW DELHI- 110001


No.F.6/DFS/MS/School/2021/SZ/938

Dated: 17/11/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Lawrence Public School at C-3 Block, Janakpuri, New Delhi-110058, comprised of ground plus three upper floors, owned/occupied by Lawrence Public School. The building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 27/10/2021 in the presence of Sh. Sanjay Kumar (Admin.) and found that the building is fit for occupancy 'Group B "Educational Building" with effect from 17/11/2021 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....17/11/2021.....at New Delhi by

  
(Anil Garg)  
**Director**

Delhi Fire Service

To,

The Manager,

Lawrence Public School at C-3 Block, Janakpuri, New Delhi-110058.

Copy to:-

The Director of Education, Govt of NCT of Delhi, Old Secretariat,  
New Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : Lawrence Public School at C-3 Block, Janakpuri,  
New Delhi-110058.
2. Building is comprised of : G+3 upper floors.
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous FSC letter : Nil
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 27/10/2021
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer:  
From the building side : Sh. Sanjay Kumar (Admin.)
10. Year of Construction : 1985
11. Applicant's letter No : LPS/2021/2042 Dated- 27/09/2021

S. N	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m.	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	03 Nos.	03 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 m each	2X1.45 & 1X1.35 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02No.	02 No.	MR
	e. Width of Corridor	1.5 m.	1.5& 1.7 m.	MR
	f. Door Size	1.0 m	1.0 & 1.20 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	08 nos.	Provided	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	IS I marked	ISI marked	MR

6	First-aid-Hose Reels.				
	Total numbers of each floor	01 Nos.	Provided	MR	
	• Length of hose reel hose	30mtr.	Provided	MR	
	• Nozzle diameter	05mm	Provided	MR	
7	Automatic fire detection and alarming system.				
	• Type of detectors	N/A	N/A	N/A	
	• Location of main panel	N/A	N/A	N/A	
	• Location of repeater panel	N/A	N/A	N/A	
	• Alternate source of power	N/A	N/A	N/A	
	• Hooter's location	N/A	N/A	N/A	
8	MOEFA	N/A	N/A	N/A	
9	Public address System.	N/A	N/A	N/A	
10	Automatic Sprinkler System.				
	• Basement	N/A	N/A	N/A	
	• upper floor	N/A	N/A	N/A	
	• sprinkler above false ceiling	N/A	N/A	N/A	
11	Internal Hydrants				
	• size of riser/down-comer	100 mm	Provided	MR	
	• Number of hydrants per floor	1 Nos.	Provided	MR	
	• Hose Box	1 Nos.	Provided	MR	
12	Yard Hydrants.				
	• Total number of hydrants	N/A	N/A	N/A	
	• Hose Box	N/A	N/A	N/A	
13	Pumping Arrangements.				
	• Ground Level				
	➤ Discharge of main Pump	N/A	N/A	N/A	
	➤ Head of Main Pump	N/A	N/A	N/A	
	➤ Number of main pumps	N/A	N/A	N/A	
	➤ Jockey pump out put	N/A	N/A	N/A	
	➤ Jockey pump head	N/A	N/A	N/A	
	➤ Standby pump out put	N/A	N/A	N/A	
	➤ Standby pump Head	N/A	N/A	N/A	
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A	
	➤ Pump House Access	N/A	N/A	N/A	
	• Terrace Level				
	➤ Discharge of pump	450 LPM	Provided	MR	
	➤ Head of the Pump	40 M	Provided	MR	
	➤ Power supply	Required	Provided	MR	
	➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for Fire Fighting.				
	• Underground tank capacity	N/A	N/A	N/A	
	➤ Draw-off connection	N/A	N/A	N/A	
	➤ Fire service inlet	N/A	N/A	N/A	
	➤ Access to tank	N/A	N/A	N/A	
	• Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs	MR	
15	Exit Signage.	Required	Provided	MR	

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection. The shortcomings was issued vide letter no. F6/DFS/MS/School/2021/SZ/476 dated 08/09/2021 has been complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety as required under the rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate.

*R. K. Yadav*

Signature of the Inspecting Officer <sup>29/10/2021</sup>  
 Name- R.K. Yadav  
 Designation- ADO(JKP)

DO(South West)

*[Handwritten signatures and dates]*  
 03/11/2021  
 Dy cfo (S2)  
 8/11  
 C/F/O -  
 9/11  
 7/11/2021  
 Anuj K

