

C-23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 942

Dated: 17/11/2021

FIRE SAFETY CERTIFICATE

Certified that **M.C. Primary Boys School (ID- 1556124) located at Bkkarwala Village S.D.M.C. West Zone, New Delhi- 110041**, comprised of ground and first floor only, was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2018/WZ/2739 dated 20.12.2018. The school building was re-inspected by the officer concerned of this department on 08.11.2021, in the presence of Sh. Devender Kumar (Primary Teacher) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular no. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01.03.2011 and that the building/premises is fit for occupancy class "Educational" with effect from 17/11/2021 for a period of three years, subject to compliance of the conditions, printed overleaf.

Issued on 17/11/2021 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Principal,
M.C. Primary Boys School (ID- 1556124),
Bakkarwala Village, New Delhi- 110041.
2. The Directorate of Education,
NDMC, SPM Civic Centre,
J.L.N Marg, Delhi- 110002.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

N/12

INSPECTION REPORT

1. Name & address of the building : M.C. Primary Boys School, Bakkarwala, New Delhi- 41.
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal
 4. Details of previous NOC : F6/DFS/MS/School/2018/WZ/2739 dated 20/12/2018
 5. Fire Safety directives letter No : D.o.E cir. F6/Estate/CC/Fire/Safety/2011/3298-3398 dt. 01.03.2011
 6. Date of inspection : 08.11.2021
 7. Name of the Inspecting Officers : Aman Kumar Lathar, ADO (JWP)
 8. Name and designation of officers
from the building side : Sh. Devender Kumar, Primary Teacher
 9. Year of Construction : 2005
 10. Applicant's letter No. : E-mail dt. 28.10.2021
- M.C. Primary Boys School is comprised of ground and first floor only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.50 mts	1.50 & 1.40 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 No.	Provided	MR
	g. Width of Corridor	1.5 mts	1.5 mts	MR
	h. Door Size	1.0 mt	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			

Ch

	<ul style="list-style-type: none"> Total numbers Types IS marking 	05 nos. ABC, CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	--- N/A	---- N/A	----- N/A
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	Not Applicable			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A

2/14

	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2018/WZ/2739 dated 20/12/2018, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DFA is put up for approval & signature please.

[Handwritten signature]
08/11/21

Signature of the Inspecting Officer
(Aman Kumar Lathar)
Asst. Divisional Officer (JWP)

D.O. (West Division)

181
9/11/2021
DFO (WZ)

[Handwritten signature]
09/11/2021
[Handwritten signature]
11/11/2021

Asst JWP

DFO (WZ)

F.T. letter is put-up for signature pl.

[Handwritten signature]
15/11/2021

[Handwritten signature]
12/11/21
Asst (JWP)

ms/ cell