

439

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2021/School/943

Dated: 17/11/2021

**FIRE SAFETY CERTIFICATE**

Certified that the building Neo Great Mission Public School, Located at Sector - 5 Dwarka, New Delhi – 110075 comprised of Ground + 02 Upper Floor was issued Fire Safety Certificate by this department vide Letter no. F6/DFS/MS/School/2017/SZ/788 Dated 02-06-2017. The premises was re inspected by the officer concerned of this department on 09/11/2021 in the presence of Ms. Radha Ghai (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class B "Educational" with effect from 17/11/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/11/2021 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. Neo Great Mission Public School, Located at Sector - 5 Dwarka, New Delhi – 110075.

**Following fire safety directives must be adhered to:-**

- 1 The temporary rooms erected in the premises shall not be used for school activities.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 8 Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/19  
**INSPECTION REPORT**

1. Name & address of the building: Neo Great Mission Public School, Located at Sector - 5 Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational ( Ground + 2 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/SZ/788 Dated 02-06-17
5. Fire Safety directives Letter No. : 2011/3298 Dated 01/03/2011
6. Date of inspection : 09/11/2021
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms. Radha Ghai (Manager)
9. Year of Construction : 2000
10. Applicant's letter No. : Email Dated 05-11-2021

|                                    |
|------------------------------------|
| No. of Students=398                |
| No. of class rooms=12              |
| Plot area=800 M <sup>2</sup>       |
| Covered area=797.85 M <sup>2</sup> |

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC/DOE Circular no-01/03/2011 | Provided at site    | Remarks<br>MR/NMR |
|------|---|--------------------------------|---------------------|-------------------|
| 1.   | Access of building  |                                |                     |                   |
|      | • Road width  | 06 mtr                         | 09 mtr              | MR                |
|      | • Gate width  | 05 mtr                         | 05 mtr              | MR                |
|      | • Width of internal road                                    | NA                             | NA                  | NA                |
| 2.   | Number, width, Type & Arrangements of exits                 |                                |                     |                   |
|      | a. Number of staircases                                     |                                |                     |                   |
|      | • Upper floors  | 02 Nos.                        | 02 Nos.             | MR Old case       |
|      | • Basements   | NA                             | NA                  | NA                |
|      | b. Width of staircases                                      |                                |                     |                   |
|      | • Upper floors  | 1.5 m & 0.75 m                 | 152 cm & 75 cm      | MR Old case       |
|      | • Basements   | NA                             | NA                  | NA                |
|      | c. Protection of exits                                      |                                |                     |                   |
|      | • Fire check door   | NA                             | NA                  | NA                |
|      | • Pressurization  | NA                             | NA                  | NA                |
|      | d. No of continuous staircase to terrace                    | 1                              | 01                  | MR                |
|      | e. Width Of Corridor  | 1.5m                           | 198 cm              | MR                |
|      | f. Door Size  | 1m                             | 112cm               | MR                |
| 3.   | Compartmentation  |                                |                     |                   |
|      | • Fire check door   | NA                             | NA                  | NA                |
|      | • Sealing of electrical shafts                              | NA                             | NA                  | NA                |
|      | • Fire Rating of shaft door                                 | NA                             | NA                  | NA                |
|      | • Water Curtain   | NA                             | NA                  | NA                |
|      | • Fire Dampers  | NA                             | NA                  | NA                |
| 4.   | Smoke managements System                                    |                                |                     |                   |
|      | • Basements   | NA                             | NA                  | NA                |
|      | • Upper floors  | 12 a/c charge                  | Natural ventilation | NA                |

N/20

|     |  |                       |                       |    |
|-----|--|-----------------------|-----------------------|----|
| 5.  | Fire Extinguishers                           |                       |                       |    |
|     | • Total numbers                              | 06 nos.               | 12 Nos.               | MR |
|     | • Types                                      | ABC & CO <sub>2</sub> | ABC & CO <sub>2</sub> | MR |
|     | • IS marking                                 | ISI marked            | Provided              | MR |
| 6.  | First – Aid Hose Reels                       |                       |                       |    |
|     | • Total numbers on each floor                | 01                    | Provided              | MR |
|     | • Length of hose reel hose                   | 30m                   | 30m                   | MR |
|     | • Nozzle diameter                            | 5mm                   | 5mm                   | MR |
| 7.  | Automatic fire detection and alarming system |                       |                       |    |
|     | • Type of detectors                          | NA                    | NA                    | NA |
|     | • Location of Main Panel                     | NA                    | NA                    | NA |
|     | • Location of Repeater Panel                 | NA                    | NA                    | NA |
|     | • Alternate source of power                  | NA                    | NA                    | NA |
|     | • Hooters' Location                          | NA                    | NA                    | NA |
| 8.  | MOEFA  | NA                    | NA                    | NA |
| 9.  | Public Address System                        | NA                    | Provided              | NA |
| 10. | Automatic Sprinkler System                   |                       |                       |    |
|     | • Basements                                  | NA                    | NA                    | NA |
|     | • Upper Floor                                | NA                    | NA                    | NA |
|     | • Sprinkler above false ceiling              | NA                    | NA                    | NA |
| 11. | Internal Hydrants:                           |                       |                       |    |
|     | • Size of riser/down- comer                  | NA                    | 100 mm                | NA |
|     | • Number of hydrants per floor               | NA                    | 01                    | NA |
|     | • Hose Box                                   | NA                    | 01                    | NA |
| 12. | Yard Hydrants                                |                       |                       |    |
|     | • Total number of hydrants                   | NA                    | NA                    | NA |
|     | • Hose Box                                   | NA                    | NA                    | NA |
| 13. | Pumping Arrangements:                        |                       |                       |    |
|     | • Ground Level                               |                       |                       |    |
|     | • Discharge of main pump                     | NA                    | NA                    | NA |
|     | ➤ Head of main pump                          | NA                    | NA                    | NA |
|     | ➤ Number of main pumps                       | NA                    | NA                    | NA |
|     | ➤ Jockey pump out put                        | NA                    | NA                    | NA |
|     | ➤ Jockey pump head                           | NA                    | NA                    | NA |
|     | ➤ Standby Pump out put                       | NA                    | NA                    | NA |
|     | ➤ Standby Pump Head                          | NA                    | NA                    | NA |
|     | ➤ Auto Staring/Manual stopping               | NA                    | NA                    | NA |
|     | ➤ Pump House Access                          | NA                    | NA                    | NA |
|     | • Terrace level                              |                       |                       |    |
|     | ➤ Discharge of pump                          | 450 lpm               | Provided              | MR |
|     | ➤ Head of the pump                           | 40Mtr                 | 40 mtr                | MR |
|     | ➤ Power supply                               | Required              | Provided              | MR |
|     | ➤ Auto starting of pump                      | Required              | Provided              | MR |
| 14. | Captive water Storage for fire fighting:     |                       |                       |    |
|     | • Under ground tank capacity                 | NA                    | NA                    | NA |
|     | ➤ Draw off connection                        | NA                    | NA                    | NA |
|     | ➤ Fire service inlet                         | NA                    | NA                    | NA |
|     | ➤ Access to tank                             | NA                    | NA                    | NA |
|     | • Overhead Tank capacity                     | 10,000Ltr             | Provided              | MR |

N/21

|    |  |          |  |    |
|----|--|----------|--|----|
| 15 | Exit Signage   | Required | Provided   | MR |
| 16 | Provision of Lifts   |          |  |    |
|    | ➤ Pressurization of Lift Shaft   | NA       | NA   | NA |
|    | ➤ Pressurization of lift lobby   | NA       | NA   | NA |
|    | ➤ Communication in lift Car  | NA       | NA   | NA |
|    | ➤ Fireman's Grounding Switch   | NA       | NA   | NA |
|    | ➤ Lift Signage   | NA       | NA   | NA |
| 17 | Standby power supply   | NA       | NA   | NA |
| 18 | Refuge Area  |          |  |    |
|    | ➤ Total area   | NA       | NA   | NA |
|    | ➤ Location   | NA       | NA   | NA |
| 19 | Fire control room  |          |  |    |
|    | ➤ Detector system panel  | NA       | NA   | NA |
|    | ➤ Flow Switch Panel  | NA       | NA   | NA |
|    | ➤ PA System Panel  | NA       | NA   | NA |
|    | ➤ Battery backup   | NA       | NA   | NA |
|    | ➤ Building Floor Plans   | NA       | NA   | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any; | NA       | ABC fire extinguisher provided near electric panel | MR |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2017/SZ/788 Dated 02-06-2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note: The temporary term, shall not be used for school activities

Signature of the Inspecting Officer

Name Uday Vir Singh

Designation ADSO/DWR

Del SW - on leave

Dye P/S2

Room be removed first

ADSO (DWR)

spoken, Sir rooms (Temporary) at ground floor being used as guard room & office.

Dye P/S2

ADSO/DWR

ADSO/DWR