

E-41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/School/WZ/2021/937

Dated: 12/11/2021

**FIRE SAFETY CERTIFICATE**

Certified that Pooja Educational & Cultural Society located at Zone-H, H-4 & 5, Pitampura, Delhi- 110034, comprised of basement, stilt, ground plus two upper floors, owned/occupied by Pooja Educational & Cultural Society, was inspected by the officer concerned of this department on 11.11.2021 in the presence of Sh. Rajeev Gupta, Director, Sh. Neeraj Gupta, A.E. MCD & Sh. Iqbal Umar Khan, J.E. MCD and found that the school building have complied with the fire prevention and fire safety requirements in accordance with Rule- 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and that the building/premises is fit for occupancy class "Educational" with effect from 12/11/2021 for a period of three years, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules- 2010, printed overleaf.

Issued on 12/11/2021 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Director, Pooja Educational & Cultural Society,  
Zone-H, H-4 & 5, Pitampura,  
Delhi- 110034.
2. The Directorate of Education, Old Secretariat, Delhi- 110054.
3. The Executive Engineer (Building) HQs,  
9<sup>th</sup> Floor, civic Centre, Minto Road, New Delhi- 110002.

9C   
12/11/2021

## Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement floor shall be used as per building bye-laws.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

## INSPECTION REPORT

1. Name & address of the building : Pooja Educational & Cultural Society, Zone-H, H-4 & 5, Pitampura, Delhi- 110034.
2. Type of Occupancy : Educational (Basement, stilt, ground plus two upper floors)
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2019/94 dated 08.03.2019
6. Date of inspection : 21.10.2021
7. Name of the Inspecting Officers: M.K. Chattopadhyay, DO (West),
8. Name and designation of officers from the building side : Sh. Rajeev Gupta, Director, Sh. Neeraj Gupta (A.E. MCD), Sh. Iqbal Umar Khan, J.E. MCD
9. Year of Construction : 2021-22
10. Applicant's letter No. : Online ID 10094069

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ UBBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts each	Provided	MR
	• Basements	1.5 mts each	Provided	MR
	c. Protection of exits	-----	-----	-----
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	Provided	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1.20 mt.	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR






	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	15,000 lts	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>	<b>Not Yet Energized</b>		
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required as per Delhi Fire Service Act- 2007 under Delhi Fire Service Rules- 2010, it is recommended to grant fire safety certificate in accordance with the rules.


Accordingly, DFA is put up please.


264/DO/WD  
12/11/2021

  
 11/11/2021  
 Signature of the Inspecting Officer  
 Divisional Officer (WD)

DCFO (WZ) - CL

Cfo - not available in the office. It is a online case & time bound.

Director   
12/11/21

F.T. letter is put up for Sign please  
  
 12/11/2021