

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/H/2021/SZ/ 566

Dated: 17 / 11 / 2021


FIRE SAFETY CERTIFICATE

Certified that the **Warehouse namely Air Cargo Logistics Centre (ACLC II)** situated at **IGI Airport, New Delhi-110037** (for Shristi Cargo Warehouse Pvt. Ltd), comprised of ground floor (Shed) only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/H/SZ/2018/2552 dated 26/11/2018. The premise was re-inspected by the officers concerned of this department on 09/11/2021 in the presence of Mr. Amit Chhabra and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Group 'H' (Storage)** with effect from the 17 / 11 / 2021 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17 / 11 / 2021 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



Copy to: -

1. Sh. Ritesh Yarlagadda (CEO), M/s Shristi Cargo Warehouse Pvt. Ltd., Office Block, Air Cargo Logistics Centre-II, Opp. Gate 6, Cargo Terminal, IGI Airport, New Delhi-110037
2. The C.E.O, DIAL, New Udaan Bhawan, Opp. T-3, IGI Airport, New Delhi-110037

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	Warehouse namely Air Cargo Logistics Centre (ACLC-II) at IGI Airport, New Delhi-110037 (for Shristi Cargo Warehouse Pvt. Ltd)		
2	Type of Occupancy	Group -H (Storage Building)		
3	Building Comprised of	Ground Floor (Shed) only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/H/SZ/2018/2552 dated 26/11/2018		
6	Fire Safety Directives Letter No	F.6/DFS/MS/2018/3614 dated 23/08/2018		
7	Date of Inspection	09/11/2021		
8	Name of the Inspecting Officers	DO (SD) & ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Amit Chhabra (Project Manager)		
10	Year of Construction	2018		
11	Applicant letter No.	E-mail dated 12/10/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	➤ Road width	6m	Provided	MR
	➤ Gate width	4.5m	Provided	MR
	➤ Width of internal road	As per plan	6m	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	28 x 1.5m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain/Roof Screen/Curtain Board	Required	Provided	MR
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Ground / Upper floors	Annex. M	Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	Required ABC/CO ₂ /W.CO ₂ /Foam ISI marked	80 Nos	MR
	• Types		25/25/15/15	MR
	• ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	Required	16 Nos	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR

7	Automatic fire detection & alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	All Areas	All Areas	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement.	-NA-	-NA-	-NA-
	• Ground floor	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	Required	16 Nos	MR
	• Hose box.	Required	16 Nos	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	28 Nos	MR
	• Hose box	Required	28 Nos	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	2850 LPM	Provided	MR
	➤ Head of main pump.	70m	Provided	MR
	➤ Number of main pumps.	One	Provided	MR
	➤ Jockey Pump output.	180 LPM	Provided	MR
	➤ Jockey Pump head.	70m	Provided	MR
	➤ Standby Pump output.	2850 LPM	Provided	MR
	➤ Standby Pump head.	70m	Provided	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump house access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	40m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	• Underground tank capacity	2,00,000 Ltrs	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	10,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

10	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Manual gas flooding/linear heat sensing tubes with CO ₂ cylinder in HT & LT panel.		MR

The fire protection system provided in the building/ premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/H/SZ/2018/2552 dated 26/11/2018, renewal under Rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly, DFA is put up for approval and signature please.

AK Jaiswal

S.K. Dua
11/11/21

Signature of the Inspecting Officer
Name : S.K Dua
Designation: DO (SD)

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation: ADO (SJ)

[Signature]
12/11

DCFO (SZ)

F.T. letter is put up for sig- pl.

S.K. Dua
17/11/21

DCFO (SZ)
[Signature]
17/11

A.N.S. - [Signature]