

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021 / CNG / WZ / 573

Dated: 18/11/2021

FIRE SAFETY CERTIFICATE

Certified that the **Bee Gee Motors** located at **Sector-B , DSIIDC Complex ,Narela, Delhi-110040** comprised of **Ground floor only** owned/ occupied by **Bee Gee Motors** was issued fire safety certificate by this department vide letter no. **F6./DFS/MS/2018/WZ/1550 dated 03.07.2018**. The premises was inspected by the officer concerned of this department on 01.11.2021 in the presence of **Smt. Beena P. Desai , Proprietor** and observed that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy "**Storage of Petroleum Class A & B & Group 'J'**" with effect from 18/11/2021..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/11/2021 at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
WEST ZONE

Copy to :-

1.M/s Bee Gee Motors, Sector-B, DSIIDC Complex, Narela, Delhi-110040.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Bee Gee Motors (Petrol Pump & CNG dispensing station), Sector-B, DSIIDC Complex, Narela, Delhi-110040
2. Type of Occupancy : Storage of Petroleum Class A & B & Group 'J' (Ground floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/WZ/1550 dated:03.07.2018
5. Fire Safety directives letter No : F.5/(3A)/DFS/BP/2004/323 dated-23/06/2004
FS/C340/DF3/2010/CNG/211 dated- 12.07.2010
6. Date of inspection : 01/11/2021
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Smt. Beena P. Desai (Proprietor)
9. Year of Construction : ---
10. Applicant's letter No. : E Mail id dated 28.10.2021

| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------------|---|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 08m | 18m | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| f. Door Size | 1.0m | 1.0m | MR | |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | 30 a/c per hour | NA | NA |

Beena P. Desai

N-10

| | | | | |
|---|--|-----------------|----------|-----|
| 5 | <ul style="list-style-type: none"> Upper floors | 12 a/c per hour | NA | NA |
| | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types ISI marking | 12 nos | 16 nos | MR |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Length of hose reel hose | NA | NA | NA |
| | <ul style="list-style-type: none"> Nozzle diameter | NA | NA | NA |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors | NA | NA | NA |
| | <ul style="list-style-type: none"> Location of Main Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Location of Repeater Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Alternate source of power | NA | NA | NA |
| | <ul style="list-style-type: none"> Hooters' Location | NA | NA | NA |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement | NA | NA | NA |
| | <ul style="list-style-type: none"> Upper Floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer | NA | NA | NA |
| | <ul style="list-style-type: none"> Number of hydrants per floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Hose Box | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants | NA | NA | NA |
| | <ul style="list-style-type: none"> Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Discharge of pump | NA | NA | NA |
| | <ul style="list-style-type: none"> Head of the pump | NA | NA | NA |
| | <ul style="list-style-type: none"> Power Supply | NA | NA | NA |
| | <ul style="list-style-type: none"> Discharge of main Pump | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Head of Main pump | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Number of main pumps | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Jockey Pump out put | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Jockey pump head | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Standby Pump out put | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Standby Pump Head | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Auto Starting/ Manual stopping | N/A | N/A | N/A |
| <ul style="list-style-type: none"> Pump House Access | N/A | N/A | N/A | |

a-11

| | | | | |
|----|--|---|-----|-----|
| | ➤ Auto Starting of pump | NA | NA | NA |
| | | NA | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage. | NA | NA | NA |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | Fire buckets filled with sand, No smoking boards were found displayed in Hindi & English. No loose electric wiring were seen in premises & Co2 flooding system found provided | | MR |
| | | | | |

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of deemed compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter no. F/6/DFS/MS/2018/WZ/1550 dated 03.07.2018 under rule 35 of the Delhi Fire Service Rules 2010.

Defo (WZ)

15/11/2021

*ADO (BW)
11/11/21*

Signature of the Inspecting Officer
Name: - Rajeev Kumar Sinha

Designation- ADO/BW

ADO/BW

P.T.O