

C to

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2021/SZ/ 342

Dated: 24/11/2021

**FIRE SAFETY CERTIFICATE**

Certified that M/s Haldiram (A Unit of Haldiram Marketing Pvt. Ltd) located at Shop No M-01 & M-02, Ground Floor, DLF Avenue, A-4, District Center, Saket, Delhi 110017 in the building comprised of 03 tiers Basement, Ground + 07 Upper Floor have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of department on 09/11/2021 in the presence of Sh. Sanjeev Yadav and that the premise is fit for occupancy class **Group-D Assembly** (Eating House running at Ground floor only) with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/11/2021 at New Delhi by

  
**(ATUL GARG)**  
**DIRECTOR**

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016 (Ref. MHA Portal ID No 2021091521461 dated 16/09/2021)
3. M/s Haldiram (A Unit of Haldiram Marketing Pvt. Ltd) at Shop No M-01 & M-02, Ground Floor, DLF Avenue, A-4, District Center, Saket, Delhi 110017

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/y

### INSPECTION REPORT

1	Name & Address of the Building	M/s Haldiram Marketing Pvt. Ltd, Shop No M-01 & M-02, Ground Floor, DLF Avenue, A-4, District Center, Saket, Delhi 110017		
2	Type of Occupancy	Group-D Assembly Building. (Restaurant is running at Ground Floor only)		
3	Building Comprised of	03 tier Basements, Ground + 07 Upper Floors		
4	Type of Case	New case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	DLF Place Mall,- F.6/MS/DFS/BP/2005/2073 dated 04/10/2005 & F.6/MS/DFS/BP/2019/135 dated 01/04/2019		
7	Date of Inspection	09/11/2021		
8	Name of the Inspecting Officers	[Signature] ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Sanjeev Yadav		
10	Year of construction	2006		
11	Applicant letter No.	MHA Portal ID No 2021091521461 dated 16/09/2021		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Requirement/ Existing Fire Protection</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>	( DLF Place Mall - F.6/DFS/MS/Mall/2019/SZ/1832 Dt. 23/09/2019)		
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Restt. within DLF Promenade Mall	Provided by Mall N/A N/A	MR N/A N/A
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>	Provided & Maintained by DLF Place, Saket		
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement floor.	N/A	N/A	N/A
	<b>b) Width of Staircase</b>	Provided & Maintained by DLF Place, Saket		
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>	Provided & Maintained by DLF Place, Saket		
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	02 required (1.50 m each)	1.50 m each	MR
<b>3</b>	<b>Compartmentation.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers.</li> </ul>	Restt within Mall	As above	MR
		Restt within Mall	As above	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	30 ACPH	N/A	N/A
		12 ACPH	Exhaust Fans Provided	MR
<b>5</b>	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>	Required	08 Nos	MR
		ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
		Required	Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> <li>• Length of hose-reel hose.</li> <li>• Nozzle Diameter</li> </ul>	One near Restt	As above	MR
		30m	As above	MR
		5mm	As above	MR
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>	(Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> </ul>	Required	Smoke & heat	MR
		Required	As above	MR
		Required	As above	MR

N/S

	<ul style="list-style-type: none"> <li>• Alternate source of power</li> <li>• Hooter's location</li> </ul>	Required	As above	MR
8	<b>MOEFA</b>	Required	As above	MR
9	<b>Public Address System</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System</b>	N/A	As above	MR
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Ground floor.</li> <li>• Sprinkler above false ceiling</li> </ul>	Provided & Maintained by DLF Place, Saket		
		Required	As above	MR
		Required	As above	MR
		N/A	N/A	N/A
11	<b>Internal Hydrants.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> <li>• Number of Hydrant per floor</li> <li>• Hose box.</li> </ul>	Required	As above	MR
		One near Restt	As above	MR
		One near Restt	As above	MR
12	<b>Yard Hydrants.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> <li>• Hose box.</li> </ul>	N/A	As above	N/A
		N/A	As above	N/A
13	<b>Pumping arrangements.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b></li> </ul>	<b>Common pumping arrangements for entire bldg</b>		
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> <li>➤ Head of main pump.</li> <li>➤ Number of main pumps.</li> <li>➤ Jockey Pump output.</li> <li>➤ Jockey Pump head.</li> <li>➤ Standby Pump output.</li> <li>➤ Standby Pump head.</li> <li>➤ Auto Starting/Manual Stopping.</li> <li>➤ Pump house access.</li> </ul>	4500 LPM	4500 LPM	MR
		70m	70m	MR
		02 Nos.	02 Nos.	MR
		180 LPM	180 LPM	MR
		70m	70m	MR
		4500 LPM	2 X 4500 LPM	MR
		70m	70m	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> <li>• <b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> <li>➤ Head of pump.</li> <li>➤ Power supply.</li> <li>➤ Auto starting of pump.</li> </ul>	450 LPM	As above	MR
		40 m	As above	MR
		Required	As above	MR
		Required	As above	MR
14	<b>Captive water storage for fire fighting.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Underground tank capacity.</li> <li>➤ Draw-off connection.</li> <li>➤ Fire Service Inlet.</li> <li>➤ Access to tank.</li> <li>• Overhead tank capacity.</li> </ul>	Required	3,70,000 Ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	30,000 Ltrs	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> <li>• Pressurization of lift lobby.</li> <li>• Communication in lift car.</li> <li>• Fireman's switch.</li> <li>• Lift signage.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	<b>Fire Control Room.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

N/G

20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A
----	--	-----	-----	-----

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

*RLK*  
11/11/2021

Signature of the inspecting Officer  
Name: Sh. Rajesh Kumar  
Designation: ADO (BCP)

DO (SD)

*RLK*  
12/11

DCFO (S2)

*[Signature]*  
12/11

CFO

*[Signature]*  
16/11



~~*[Signature]*~~  
16/11/2021

*[Signature]*

~~*[Signature]*~~

As approved, F-1. ~~letter~~ in ~~part~~ for your signature @

Director  
*[Signature]*  
29/11/21

*RLK*  
29/11