

1-26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/EH/2021/SZ/ 338

Dated: 24/11/21

FIRE SAFETY CERTIFICATE

Certified that the **M/s KFC Restaurant (A unit of sapphire foods)**, Shop No.-8 to 11, Plot No.-19, Satyam Complex, District Centre, Janakpuri, New Delhi-110058, is running at ground floor was issued FSC by this department vide letter no. F6/DFS/MS/EH/2018/SZ/2307 dated 12/10/2018 owned/occupied by M/s KFC Restaurant (A unit of sapphire foods) was re-inspected by the officers concerned of this department on 11/11/2021 in the presence of Sh. Amit Kumar (Manager) and found that the restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground Floor Only**) is fit for occupancy class Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....24/11/21..... at New Delhi.



(SUNIL CHAUDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Manager,
M/s KFC Restaurant (A unit of sapphire foods), Shop No.-8 to 11, Plot No.-19, Satyam Complex, District Centre, Janakpuri, New Delhi-110058
2. The Dy. Health Officer,
S.D.M.C, Public Health Department, West Zone,
Vishal Enclave, Rajouri Garden, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/17

INSPECTION REPORT

1. Name & address of the building: M/s KFC Restaurant (A unit of sapphire foods), Shop No.-8 to 11, Plot No.-19, Satyam Complex, District Centre, Janakpuri, New Delhi-58
2. Building is comprised of : Restaurant is running at ground floor in satyam complex building
3. Type of Occupancy : Group D (Assembly Building)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/EH/2018/SZ/2307 dated 12/10/18
6. Fire Safety directives letter No : N/A
7. Date of inspection : 11/11/2021
8. Name of Inspecting Officers : A.D.O. R.K.Yadav
9. Name and designation of officers From the building side : Sh. Amit Kumar (Manager)
10. Year of Construction : 2010
11. Applicant's letter No. : 2021102725291 dated 28/10/21

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 m 4.5 m 06 m	12 m Directly accessible from internal road Provided	MR MR MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	(restaurant at GF only)
	<ul style="list-style-type: none"> Upper Floors Basements 	N/A	N/A	N/A
	b. Width of staircases	N/A	N/A	(restaurant at GF only)
	<ul style="list-style-type: none"> Upper Floor Basements 	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	One	M/R
	f. Door Size	N/A	Opening in hall	M/R
		02 m	2.0 & 1.05 m	MR
3.	Compartmentation			(restaurant at GF only)
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			(Restaurant at GF only)
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 No.'s ABC/CO ₂ ISI marked	Provided Provided ISI marked	MR MR MR

N/18

6.	First-Aid Hose Reels				(Restaurant at GF only)
	• Total numbers on ground floor	One	Provided		MR
	• Length of hose reel hose	30 m	Provided		MR
	• Nozzle diameter	5 mm	Provided		MR
7.	Automatic fire detection and alarming system				
	• Type of detectors	Smoke & Heat	Provided		MR
	• Location of Main Panel	Required	G Floor		MR
	• Location of Repeater Panel	N/A	N/A		N/A
	• Alternate source of power	Required	Provided		MR
	• Hooters' Location	Required	At exit		MR
8.	MOEFA	Required	Provided		MR
9.	Public Address System	N/A	Provided		N/A
10.	Automatic Sprinkler System				(Restaurant at GF only)
	• Basement	N/A	N/A		N/A
	• Ground Floor	Required	Provided		MR
	• Sprinkler above false ceiling	N/A	N/A		N/A
11.	Internal Hydrants				(Restaurant at GF only)
	• Size of riser/down-comer	100 mm	Provided		MR
	• Number of hydrants	01 No.	Provided		MR
	• Hose Box	01 No.	Provided		MR
12.	Yard Hydrants				
	• Total number of hydrants	N/A	N/A		N/A
	• Hose Box	N/A	N/A		N/A
13.	Pumping Arrangements				(Common with satyam Complex)
	• Ground Level				
	➤ Discharge of main Pump	2280 LPM	Provided		MR
	➤ Head of Main pump	60 m	Provided		MR
	➤ Number of main pumps	One	Provided		MR
	➤ Jockey Pump out put	220 LPM	Provided		MR
	➤ Jockey pump head	60 m	Provided		MR
	➤ Standby Pump out put	2280 LPM	Provided		MR
	➤ Standby Pump Head	60 m	Provided		MR
	➤ Auto Starting/Manual Stopping	Required	Provided		MR
	➤ Pump House Access	N/A	N/A		N/A
	• Terrace level				
	➤ Discharge of pump	N/A	N/A		N/A
	➤ Head of the pump	N/A	N/A		N/A
	➤ Power Supply	N/A	N/A		N/A
	➤ Auto Starting of pump	N/A	N/A		N/A
14.	Captive Water Storage for fire fighting				
	• Underground tank capacity	Required	90,000 ltrs		MR, being old case
	➤ Draw-off connection	Required	Provided		MR
	➤ Fire service inlet	Required	Provided		MR
	➤ Access to tank	Required	Provided		MR
	• Overhead Tank capacity	Required	45000 ltrs		MR
15.	Exit Signage.	Required	Provided		MR

N/19

		(Restaurant at GF only)		
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/EH/2018/SZ/2307 dated 12/10/2018, renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

R.K. Yadav
12/11/2021

Signature of Inspecting Officer
Name:- R.K. Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

[Signature]
12/11/2021

[Signature]
16/11

ADD *[Signature]* (R.K.P.)