

C-40

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/SZ/2021/ 340

Dated: 24/11/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s **KFC Restaurant** (A unit of sapphire foods Pvt. Ltd.) Located at **Plot No. 230, Sector – 9, Dwarka, New Delhi – 110077, is running at ground & 1st floor in a building comprised of Ground + 2 Upper floor** was issued FSC by this department vide letter no. F6/DFS/MS/EH/2018/SZ/307 Dated 26/02/2018 The premises was re – inspected by the officer concerned of this department on 11/11/2021 in the presence of Sh. Madhur Sharma (Deputy Manager) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy class “ Assembly” Group D (**ground & 1st floor**) with effect from 24/11/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...24/11/21... at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Dy Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.
2. The Manager, M/s KFC Restaurant Located at Plot No. 230, Sector – 9, Dwarka, New Delhi – 110077.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s KFC Restaurant Located at Plot No. 230, Sector – 9, Dwarka, New Delhi – 110077.
2. Type of Occupancy : Assembly 'D' Restaurant running at Ground & 1st Floor,(**The building comprised of Ground + 2 Upper Floor**) :
3. Type of Case ; Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2018/SZ/307 Dated 26-02-2018
5. Fire Safety directives Letter No. :Old Case
6. Date of inspection : 11/11/2021
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Madhur Sharma (Deputy Manager)
9. Year of Construction : 2010
10. Applicant's letter No. : Email Dated 01-11-2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 06 mtr NA NA 	<ul style="list-style-type: none"> 12 mtr NA NA 	<ul style="list-style-type: none"> MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 02 Nos. NA 	<ul style="list-style-type: none"> 02 Nos. NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1.50 m & 1.20 m NA 	<ul style="list-style-type: none"> 130cm,120 cm (Old Case) NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	01	01 Nos.	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	02 mtr & 1.25 mtr	2.13 m & 1.30 m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> Required NA NA NA NA 	<ul style="list-style-type: none"> Provided NA NA NA NA 	<ul style="list-style-type: none"> MR NA NA NA NA

N/19

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c charge	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos.each floor	14 Nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Smoke	MR
	• Location of Main Panel	Ground Floor	Near office	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Battery Backup	MR
	• Hooters' Location	Required	Stairs	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm, 180 lpm	Provided	MR
	➤ Head of the pump	40Mtr	40 mtr	MR
	➤ Power supply	Required	DG Set	MR
	➤ Auto starting of pump	Required	Provided	MR

W/20

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts (Lift not in use)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2018/SZ/307 Dated 26-02-2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

1. M/s KFC Restaurant Located at Plot No. 230, Sector - 9, Dwarka, New Delhi - 110077.
2. As per letter/ plan submitted by the applicant the area of the restaurant is 253.8 m²
3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 141(253.8/1.8=141) for whole restaurant.
4. The total seating capacity comes out be 141.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADO/DWZ

ADO/DWZ - On leave / day off

(Handwritten signatures and initials)
 16/11
 ADO (Dwarka)