

C-26

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 956

Dated: 25/11/2021

FIRE SAFETY CERTIFICATE

Certified that the Building Sarvodaya Bal Vidyalaya Located at, Shahbad, Mohd. Pur, New Delhi – 110061, having 02 blocks comprised of Ground Floor only owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide Letter no. F6/DFS/MS/School/2018/SZ/561 Dated 03/04/18. The premises was re inspected by the officer concerned of this department on 12/11/2021 in the presence of Mr. M.L Meena (Principal). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the condition given below.

Issued on ... 25/11/2021 at New Delhi by.


(Sunil Chaudhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Principal, Sarvodaya Bal Vidyalaya Located at, Shahbad, Mohd. Pur, New Delhi – 110061.(School Id-1821041)
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Sarvodaya Bal Vidyalaya Located at, Shahbad, Mohd. Pur, New Delhi – 110061 .(School Id-1821041)
2. Type of Occupancy : Educational (02 Block Ground Floor Only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/561 Dated 03/04/18
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 12/11/2021
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer

from the building side : Mr. M.L Meena(Principal)

9. Year of Construction : 1957

10. Applicant's letter No. : Email dated 01/11/2021

No. of Students=571
 No. of class rooms=16
 Plot area=19622 sqm²
 Covered area=2848

Covered area-2848

S No	Minimum standards on fire prevention and fire safety U/R 33	As per-N/9	Provided at site	Remarks MR/NMR	
1.	Access of building				
	<ul style="list-style-type: none">Road widthGate widthWidth of internal road	Required	06 mtr	MR	
		NA	06mtr	NA	
		NA	NA	NA	
2.	Number, width, Type & Arrangements of exits				
	<ul style="list-style-type: none">a. Number of staircases<ul style="list-style-type: none">Upper floorsBasementsb. Width of staircases<ul style="list-style-type: none">Upper floorsBasementsc. Protection of exits<ul style="list-style-type: none">Fire check doorPressurizationd. No of continuous staircase to terracee. Width Of Corridorf. Door Size				
		NA	NA	Ground floor only	
		NA	NA	NA	
		NA	NA	Ground floor only	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	1.5 mtr	NA	
		01 mtr	Provided	MR	
3.		Compartmentation			
		<ul style="list-style-type: none">Fire check doorSealing of electrical shaftsFire Rating of shaft doorWater CurtainFire Dampers	NA	NA	NA
			NA	NA	NA
	NA		NA	NA	
	NA		NA	NA	
	NA		NA	NA	
	NA		NA	NA	

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	Required	12 Nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
	Pumping Arrangements			
13	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

w/15

14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	NA	NA	NA
15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Battery backup 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Building Floor Plans 	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2018/SZ/561 Dated 03/04/18 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name Vijay Vir Singh

Designation AOO/DWR

DGSW
16/11/21

Dy cfo (S2)

26/11

AOO (DWR)