

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/CNG/584

Dated: 25/11/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s CNG Station (IGL) Sector-5, Dwarka, New Delhi comprised of Ground Floor only was issued NOC by this department vide Letter No. F6/DFS/MS/CNG/2018/1223 dated- 24/05/2018. The premises was re inspected by the officer concerned of this department on 30/10/2021 in the presence of Sh. Satya Prakash (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Hazardous" (CNG filling station) with effect from 25/11/2021 for a period of three years.

Issued on 25/11/2021 at New Delhi by.

(Sunil Chaudhary)
Dy. Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Sh. Ajay Khatri DGM – Fire & Safety Indraprastha Gas Limited New Delhi.
2. Sh. Satya Prakash (Manager) M/s CNG Station (IGL) Sector-5, Dwarka, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

M/16
INSPECTION REPORT

1. Name & address of the building: M/s CNG Station (IGL) Sector-5, Dwarka, New Delhi
2. Type of Occupancy : Group J: Hazardous (CNG Filling Station)
3. Type of Case : Renewal (Ground floor only)
4. Details of previous NOC: F6/DFS/MS/CNG/2018/1223 dated- 24/05/2018.
5. Fire Safety directives Letter No. : OISD -179/F6/DFS/MS/CNG/2013/2594 Dated 27/11/2013
6. Date of inspection 30/10/2021
7. Name of the Inspecting Officer : Sh. Udayvir Singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Satya Prakash (Manager)
9. Year of Construction : 2014
10. Applicant's letter No. : Email dated 25/10/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9m	30m	MR
	• Gate width	4.5	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	01 No. up to roof level	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	01 mtr	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	01	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	1 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

20/17

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		NA	Natural ventilation	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types 	18 nos. DCP, Water cum mist foam trolley & CO ₂	22 Nos. Co ₂ 4.5 kg (Nos.) DCP Trolley of 75 kg (2 Nos.) DCP 10 kgs. (15 Nos.) & 01 water mist cum foam Trolley	MR
	<ul style="list-style-type: none"> IS marking 	Required	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Gas & Flame	Provided in compressor package	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Ground Floor Upper Floor Sprinkler above false ceiling 	Water mist trolley	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA

2/15

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage	Required no smoking board		Provided MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided DG set 25 kva	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

2/19

20. Special Fire Protection Systems for Protection of special Risks, if any;	CO2 Flooding	Provided for compressor	MR
--	--------------	-------------------------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/CNG/2018/1223 dated- 24/05/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name

Handwritten signature and name: Uday Singh

Designation

Handwritten designation: AD/Secy

Handwritten signature and date: 28/11/2018

Handwritten signature and date: 08/11/2018

Handwritten text: Dy. Chg. (S2)

Handwritten signature and date: 8/11

Handwritten text: C.F.O.

Handwritten signature and date: 12/11

Handwritten signature and date: 12/11/18

Handwritten signature and date: 12/11/18

Handwritten text: Sir + letter is but up for sign for

