

(-7)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2021/SZ/ 957

Dated: 25/11/21

FIRE SAFETY CERTIFICATE

Certified that the Vijay Vidya Niketan(Vijay Vidya Niketan Educational Society), running at ground floor only is a building comprised of ground plus one upper floor located at A-110A, Sainik Enclave, Vikas Nagar, New Delhi-110059, owned/occupied by Vijay Vidya Niketan Educational Society was issued Fire Safety Certificate by this department vide letter No F6/DFS/MS/School/2015/SZ/2151 dated 10/12/2015.The school building was re-inspected by the officer concerned of this department on dated 15/11/2021 in the presence of Mr. Panwar and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and found that the building (**Ground Floor Only**) is fit for occupancy Group B 'Educational Building' with effect from ...25/11/21... for a period of three years, subject to conditions printed overleaf.

Issued on.....25/11/21.....at New Delhi by



(Sunil Chawdhary)

Dy. Chief Fire Officer

Copy to:-

1. The Manager, Vijay Vidya Niketan(Vijay Vidya Niketan Educational Society),
A-110A, Sainik Enclave, Vikas Nagar, New Delhi-110059.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/S
INSPECTION REPORT

1. Name & address of the building : Vijay Vidya Niketan(Vijay Vidya Niketan Educational Society), A-110A, Sainik Enclave, Vikas Nagar, New Delhi-110059.
2. Building is comprised of : G+1 But school running at **ground floor only**
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/D/S/MS/school/2015/S//2151 Dt.- 10/12/2015
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011
7. Date of Inspection : 15/11/2021
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer from the building side : Mr. Panwar
10. Year of Construction : 2006
11. Applicant's letter No : Nil Dated -08/11/2021

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	06 m	MR
	Gate width	----	2.35 & 1.2 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	N.A.	N.A.	Ground Floor Only
	Basement	N.A.	N.A.	No basement
	B. Width of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	Ground Floor Only
	c. Protection of exits			
	Fire check door	N.A.	N.A.	No basement
	Pressurization	N.A.	N.A.	
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	N.A.	N.A.	N.A.
		1 m	1.05 & .85 m	MR old case
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	N.A.	N.A.	N.A.

	Fire Extinguisher			
	Total numbers	04 Nos.	04 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
	MOEFA	N.A.	N.A.	N.A.
	Public address System.	N.A.	N.A.	N.A.
	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
	14 Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
	15 Exit Signage.	N.A.	N.A.	N.A.

16	Provision of Lifts.	N.A.	N.A.	N.A.
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.	N.A.	N.A.	N.A.
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room	N.A.	N.A.	N.A.
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC was issued vide letter no. F.6/DFS/MS/school/2015/SZ/2151 Dated- 10/12/2015 renewal under the Circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 is recommended.

Note :- As per ^{undertaking} the submitted by manager of the school placed at (C-5), there are less than 45 students in each classroom and school is comprised of ground plus one upper floor, but only ground floor is being used for school.

R K YADAV
16/11/2021

Signature of the Inspecting Officer
Name R K YADAV
Designation ADO (JKP)

DO (South West)

K. Jyoti
18/11/2021
By CFO (S2)

F.T.
18/11

F.T letter is put up for signature please

Dy CFO (S2)

M.S. Cell

R K YADAV
23/11/2021