

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F 6/DFS/MS /2021/ 01

Dated: 30/11/2021

FIRE SAFETY CERTIFICATE

Certified that the **Grand Imperia Banquet (A Unit of Wonder Hospitality)** located at **A-07, G.T. Karnal Road Industrial Area, Delhi-110033** comprised of **Basement, Ground, Mezzanine, First & Second floors Only** owned/ occupied by **Grand Imperia Banquet** was issued fire safety certificate vide letter no. **F6/DFS/MS/2018/2690 dated 12.12.2018**. The premises was re-inspected by the officer concerned of Fire Service on **17.11.2021** in the presence of **Sh. Ranjan Puri** and observed that all the fire prevention and fire safety arrangements as provided in the premise found good working condition. The premise have therefore deemed complied with the fire prevention and fire safety measures in accordance with the rule 33 of Delhi Fire Service Rules, 2010 and that the building / premise is fit for occupancy class "**Assembly Group D-3 (Banquet Hall)**" with effect from ~~30/11/2021~~ **30/11/2021** for a period of **three years** in accordance with rules 36 unless renewed under rule. 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/11/2021 at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph: 01125156707

Copy to : -

1. The Dy. Commissioner, (Civil Line Zone) North Delhi Municipal Corporation, 16, Rajpura Road, New Delhi-110054.
2. The Manager, Grand Imperia Banquet located at A-07, G.T. Karnal Road Industrial Area, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The use of basement shall be in accordance with the provision contained in UBBL 2016/ NBC Part 4, 2016.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**
9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

- 1 Name & address of the building : Grand Imperia Banquet , A-07, G T K Road Ind. Area, Delhi-110033.
 2 Composition of building : Basement + Ground+ Mezzanine +First floor+ Second floor only
 3 Type of Occupancy : Assembly (Banquet Hall)
 4 Type of Case : Renewal
 5 Details of previous NOC : F.6/DFS/MS/2018/2690 Dated:12.12.2018
 6 Fire Safety directives letter No : F.6/DFS/MS/2018/4329 dated : 12.10.2018
 7 Date of inspection :17.11.2021
 8 Name of the Inspecting Officers : ADO (RN)
 9 Name and designation of officers
 from the building side : Mr. Ranjan Puri
 10. Year of Construction : --
 11. Applicant's letter No. : Online Portal ID No.2021092822738 dated 02.10.2021

Total plot area— 1086.95 sqm.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	18m (approx)	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	2 m	2m	MR
	• Basements	2m	2m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
e. Width of Corridor	NA	NA	NA	
f. Door Size	2.0m	2m	MR	
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			

4/20

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	15nos	16nos	MR
		ABC & Co2	16- ABC	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
Required		Provided	MR	
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	Provided	MR
		01	01	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required,01	Provided	MR
		Required.01	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		2280lpm	2280lpm	MR
		40m	40m	MR
		NA	NA	NA
		180lpm	180lpm	MR
		NA	NA	NA
		2280 lpm	Provided	MR
		40m	40m	MR
		Required	Provided	MR
		900 lpm	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14		Captive Water Storage for fire fighting.		
	Underground tank capacity	2,00,000 ltr.	Provided	MR

N/21

	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided	MR
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 2690 dated 12.12.2018 under rule 37 of the Delhi Fire Service Rules 2010.

~~DO(N/A)~~

K
22/11/2021

Dy CPO (W2)

29/11/2021

22/11/2021

Signature of the Inspecting Officer

Name: - C.L. Meena

Designation:- ADO/RN

ADO/RN

FT letter is added for sign
30/11/2021
ADe(fow)

Dy CPO (W2)

22/11/2021

integrated MHA online Portal