

C-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/SZ/2021/ 348

Dated: 30/11/2021

FIRE SAFETY CERTIFICATE

Certified that M/s Haldiram Products private Ltd. located at ground floor, (Shop No. 6,7 & 8) and first floor (Shop No 106), ARSS Felix, , Plot No. 40, Block-A, Community Centre, Paschim Vihar, New Delhi comprised of 03 basements, ground plus four upper floors was issued FSC by this department vide letter No. F.6/DFS/MS/EH/WZ/2018/1124 dated 17-05-2018. The premises was re-inspected by the officer concerned of this department on 27.11.2021 in presence of Sh. Gaurav Verma, Manager and found owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly (restaurant) with effect from 30/11/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 30/11/2021 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer (WZ)

Copy to:-

1. Shri Madhu Sudan Agarwal,
M/s Haldiram Products private Ltd. located at ground floor, (Shop No. 6,7 & 8) and first floor (Shop No 106), ARSS Felix, Plot No. 40, Block-A, Community Centre, Paschim Vihar, New Delhi
2. The Dy. Health Officer, Public Health Department, North DMC, Rohini Zone, Sector-5, Rohini, New Delhi.
3. The Joint Commissioner Of Police (Lic.), Police Station Defence Colony, First floor, New Delhi

9c
30/11/2021

Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

N-17

INSPECTION REPORT

1. Name & address of the building: Haldiram Products private Ltd., located at ground floor, (Shop No. 6,7 & 8) and first floor (Shop No 106), ARSS Felix, , Plot No. 40, Block-A, Community Centre, Paschim Vihar, New Delhi.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/EH/WZ/2018/1124 dated 17-05-2018 (FSC also issued to the Mall vide letter No.F6/ DFS/ MS/Mercantile/WZ/2021/586 dated 26/11/21021.
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 27-11-2021
7. Name of the Inspecting Officer : Aman Lathar, ADO(JWP)
8. Name and designation of Officer
From the building side : Sh. Gaurav Verma, Manager
9. Year of Construction : 2013
10. Applicant's email date : Online ID 202112427064

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits: common with the mall			
	a. Number of staircases			
	• Upper floors	2	1 (Internal), 2 (Mall)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mts & 1.0 mts	1.5 mts(Mall) 1.2 mts (Internal stair)	MR
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door			
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	•	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 mts X 1,1 mt X 1 (Emergency door)	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR

N-18

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 nos. ABC & CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels (Provided by Mall)			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided by mall Provided by mall Provided by mall	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke Required NA NA Required	Provided Provided by mall NA NA Provided	MR MR NA NA MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA Required NA	NA Provided NA	NA MR NA
11.	Internal Hydrants: Common with the mall			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 01 Required	Provided by mall Provided by mall Provided by mall	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements: Common with the mall			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 900 LPM 40 mts Required Required	Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall	NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for firefighting: Common with the mall			
	<ul style="list-style-type: none"> Underground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA N/A NA 10, 000 litres	Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall	NA NA NA NA MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/EH/WZ/2018/1124 dated 17-05-2018, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

(Handwritten signature)
29/11/21

Signature of the Inspecting Officer
Name: Aman Lathar
Designation: ADO (JWP)

~~DO (West)~~

(Handwritten signature)
29/11/2021

~~DCFO (W2)~~

(Handwritten signature)
29/11/2021

~~ADO/WP~~

F.T. letter is put up for Sign. please!

~~DCFO (W2)~~

(Handwritten signature)
30/11/2021

(Handwritten signature)
30/11/2021

~~MS/ cell~~

FSC uploaded
30/11/2021