

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**

No. F6/DFS/MS/WZ/2021/ 588

Dated: 29/11/2021

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Golden Flacon Industries Pvt Ltd** Located at Basement + Ground Floor Plot No. 71/03, Rama Road, Najafgarh Road, Industrial Area Near Moti Nagar, New Delhi-110015 in a building comprised of **Basement + Ground Floor + 01 Upper Floor** owned/occupied by **M/s. Golden Flacon Industries Pvt Ltd**. The premises was inspected by officer concerned of this department on **17/11/2021** in the presence of Sh. Sachi Bhasin and found that the said building/Premises have complied with the fire prevention & fire safety requirements in accordance with Rule 33 of DFS Rule 2010 & the said premises is fit for occupancy class "Industry" Group G for Basement & Ground floor with effect from 29-11-2021 for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010 condition mentioned below.

Issued on... 29-11-2021 ...at New Delhi by.


Atul Garg
Director
Delhi Fire Service

Copy to:

1. The Owner/occupier M/s. Golden Flacon Industries Pvt Ltd Plot No. 71/03, Rama Road, Najafgarh Road, Industrial Area Near Moti Nagar, New Delhi-110015.
2. The Executive Engineer (Building), SDMC, Shivaji Enclave, Rajouri Garden New Delhi-110027

Following Fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Golden Falcon Industries Limited located at Plot No. 71/3, Rama Road, Najafgarh Industrial Area New Delhi- 110015
2. Type of Occupancy : G- 2 (Industrial)
3. Type of Case : New
4. Details of previous NOC : NIL
5. Fire Safety directives Letter No. : F.6/DFS/MS/BP/2021/1050 dated 13/05/2021
6. Date of inspection : 17/11/2021
7. Name of the Inspecting Officer : D.O (W) & A.D.O. (MN)
8. **Name and designation of Officer**
From the building side : Sh. Sachi Bhasin
9. Year of Construction : 1957
10. Applicant's Letter No. : Email dated 18/08 /2021

* The Said occupancy running at Basement & Ground Floor of a Building comprised of Basement, ground & 1st Floor


S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 18 mts 4.5 mts N/A 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR N/A
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> a. Number of staircases <ul style="list-style-type: none"> • Upper floors • Basements b. Width of staircases <ul style="list-style-type: none"> • Upper floors • Basements c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<ul style="list-style-type: none"> 02 02 2 nos – 1.25mts (G to Terrace) 1no – 1.25 mts (G to 1st Floor) 1.5 mts & 1.25 mts Required NR 01 NR 1.5 & 1.25 mts-basement, 1.25 mts each- upper floor. 	<ul style="list-style-type: none"> Provided Provided Provided Provided Provided NR NR NR NR provided 	<ul style="list-style-type: none"> MR MR MR MR MR NR NR NR MR MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NR NR NR NR NR 	<ul style="list-style-type: none"> NR NR NR NR NR 	<ul style="list-style-type: none"> NR NR NR NR NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> 30 a/c per hour 12 a/c per hour 	<ul style="list-style-type: none"> Exhaust Fan Provided Provided 	<ul style="list-style-type: none"> MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 10 Nos ABC /CO₂ ISI Marked 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<ul style="list-style-type: none"> 01 30 m 5 mm 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR

7.	Automatic fire detection and alarming system			MR
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat	Provided	MR
		Ground Floor	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	02	Provided	MR
		02	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2280 LPM	Provided	MR
		40 MH	Provided	MR
		01	Provided	MR
		180 LPM	Provided	MR
		40 MH	Provided	MR
		2280 LPM	Provided	MR
		40 MH	Provided	MR
		Required	Provided	MR
		Required	Provided	M.R.
		900 LPM	Provided	MR
		40 MH	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.		Captive water Storage for fire fighting		
	1. Underground tank capacity	150000 liters	Provided	MR
	2. Draw of connection	Required	Provided	MR
	3. Fire service inlet	Required	Provided	MR
	4. Access to tank	Required	Provided	MR
	5. Overhead Tank capacity	20, 000 liters	Provided	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA


20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Provided	MR
-----	--	----------	----------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/EH/WZ/2021/974 Dated 27/09/2021 have been complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.



22/11/2021

Signature of the Inspecting Officer
Name: - M. K. Chattopadhyay
Designation: - DO (West)


22/11/2021


Signature of the Inspecting officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)


316/ADO/MN
22/11/2021


25/11/2021


242
22/11/2021






26/11


26/11/2021

put up F.T.




27/11/2021

ADO (MN) Sir, F.T is put up for your personal & please


27/11/2021

