

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

NEW DELHI


No: F6/DFS/MS/Hospital/WZ/2021/ 606

Dated: 03/12/2021

FIRE SAFETY CERTIFICATE

Certified that the building of **New Block, Max Super Speciality Hospital** Located at **FC-50 Shalimar Bagh, New Delhi** comprised of **Two Basement + Mez. + Ground Floor only** owned/occupied by **A Unit of MAX Healthcare Institute Ltd.** was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/Hospital/2018/1406 dated 15.06.2021. The said Hospital building was re-inspected by the officers concerned of this department on 23.11.2021 in the presence of Sh. Anit Tushir (Fire Officer) & Sh. Anil (Engineer Head) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy "Institutional" Group - C Sub Division C - 1 with effect from 03/12/2021....for a period of three years, in accordance with rule 36 unless renewed 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service, Rules 2010, printed overleaf.

Issued on 03/12/2021..... at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. Sh. Indrajeet Kumar (General Manager), Max Health Care Institute Ltd., FC-50, Shalimar Bagh, Delhi-110088.
2. The Deputy Director (Bldg.), DDA, Building Section, C-1, 2nd floor, Vikas Sadan, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The Basement shall be used as per BBL.
10. 06 mtrs. wide access road shall always be kept clear for fire tender movement. No. parking & Scaffolding is allowed.

INSPECTION REPORT

1. Name & address of the building: **New Block, Max Super Speciality Hospital (A Unit of MAX Healthcare Institute Ltd.)** Located at **FC-50 Shalimar Bagh, New Delhi.**
2. Type of Occupancy : Institutional(**Two Basement+ Mez.+ GF**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Hospital/ 2018/1406 dated 15.06.2018
5. Fire Safety directives Letter No. :F6/DFS/MS/Hosp/2018/854 dated 09/03/2018
6. Date of inspection : 23.11.2021
7. Name of the Inspecting Officer : M.K. Chattopadhyay, DO(West) & S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer from the building side : Sh. Anit Tushir (Fire Officer) & Sh. Anil (Engineer Head)
9. Year of Construction : 2016/18
10. Applicant's letter No. : email Dated 08.11.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements/letter dated 15.06.2021	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	06 m	provided	MR
	• Width of internal road	06 m	provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper floors	2 mtrs.	Provided	MR
	• Basements	2 mtrs.	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	2.4 mtrs.	Provided	MR
	f. Door Size	2mtrs.	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	20 nos.	Provided	MR
	• Types	DCP & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

Sy


6.	First Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Each floor	Provided	NR
	• Alternate source of power	Required	Battery Backup	MR
	• Hooters' Location	Near Staircase	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants:			
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	06	Provided	MR
	• Hose Box	06	Provided	MR
13.	Pumping Arrangements:	Common with existing arrangement		
	• Ground Level			
	• Discharge of main pump	2280 lpm	Provided	MR
	➤ Head of main pump	120 m	Provided	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	120 m	Provided	MR
	➤ Standby Pump out put	2280 lpm	Provided	MR
	➤ Standby Pump Head	120 m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Accessible	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for firefighting:(Terrace Tank not provided as building comprised of 2Basement , Maz+ Ground Floor Only)			
	• Under ground tank capacity	2,00,000 litre	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Accessible	Provided	MR
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR


Sax

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

Fire Protection System Provided in the building were checked and found functional at the time inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of FSC issued vide letter no. F6/DFS/MS/Hospital/2018/WZ/1406 dated 15.06.2018 is recommended under the rule 37 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.


25/11/2021
M.K. Chattopadhyay
DO (West)


25/11/21
S.P. Bhardwaj
ADO (WP)

275
25/11/2021
DO (W2)


29/11/2021

AA/DO P

FT is put up for signat for

DO/W2


8/12/2021


2/12/21

MS/44