

- 1154
L55

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2021/SZ/ 352

Dated: 2/12/2021

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of **M/s OLIVE (A Unit of Olive Bar & Kitchen Pvt Ltd)** located at **Haveli No 6 & 8, One Style Mile, Kalka Das Marg, Mehrauli, New Delhi- 110030** comprised of ground and half floor of the building and the **restaurant is running at ground floor only** owned/occupied by (A Unit of Olive Bar & Kitchen Pvt Ltd) was issued FSC by this department vide letter no F6/DFS/MS/EH/2019/SZ/587 dated 22/03/2019. The restaurant premise was re-inspected by the officer concerned of this department on 24/11/2021 in the presence of Mr. P. J Thareja (owner) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building" (Restaurant at ground floor only)** with effect from 2/12/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 2/12/2021 at New Delhi by


**(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER**

Copy to: -

1. The Dy. Health Officer, SDMC, Public Health Department, Green Park, Aurobindo Marg, New Delhi – 110016. (Ref. MHA Portal ID 2021091621656 dated 17/09/2021)
2. The Joint Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-49.
3. M/s OLIVE (A Unit of Olive Bar & Kitchen Pvt Ltd) Plot No 6 & 8, One Style Mile, Kalka Das Marg, Mehrauli, New Delhi- 110030

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

M17
INSPECTION REPORT

1	Name & Address of the Building	M/s OLIVE (A Unit of Olive Bar & Kitchen Pvt Ltd) Plot No 6 & 8, One Style Mile, Kalka Das Marg, Mehrauli, New Delhi- 110030		
2	Type of Occupancy	Group-D Assembly Building.		
3	Building Comprised of	Ground and Half upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2019/SZ/587 dated 22/03/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	24/11/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. P. J Thareja (owner)		
10	Year of construction	2003		
11	Applicant letter No.	MHA Portal ID 2021091621656 dated 17/09/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required	9m	MR
		02 Exit	Provided	MR
		N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	N/A	02 Nos Provided	N/A
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1.50 m (old case)	02 Nos Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	30 ACPH	N/A	N/A
		12 ACPH	Exhaust Fan Provided	MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	12 Nos	Provided	MR
		ABC/CO ₂	ABC, Foam & CO ₂	MR
		ISI marked	Provided	MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	One	03 Nos	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel 	N/A	N/A	N/A
		N/A	N/A	N/A

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	NA	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground floor. Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		One	Provided	MR
		One	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 			
		450 LPM	Provided	MR
		35 m	Provided	MR
		01	Provided	MR
		180 LPM	N/A	N/A
		35 m	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	5,000 ltrs	25,000 ltrs	MR
		N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. PA system panel. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

N/A

	<ul style="list-style-type: none"> Battery backup. Building floor plan. 	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2019/SZ/587 dated 22/03/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature
25/11

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Designation: ADO (BCP)

DO (SD)

Signature
26/11/21

Signature
DO(SD)

Signature
29/11

ADO BCP

As approved, F.T. letter is put up for your signature pl.

Signature
30/11

Signature
DO(SD)

Signature