

244

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No F 6/DFS/MS/2021/School/WZ/ 970

Dated: 1/12/2021

FIRE SAFETY CERTIFICATE

Certified that the **P.S.M. Public School, Pratap Vihar, Kirari Extn. Nangloi, Delhi-86**, comprised of **Ground + Two upper floors** owned/occupied by **P.S.M. Public School** was granted FSC by this department vide letter No. **F.6/DFS/MS/School/2018/WZ/704 dated 13.04.2018**. The premises was re-inspected by the officer concerned of this department on **22.11.2021** in the presence of **Sh. Deepak (Chairman)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from **..1.12.21.....** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **...1.12.21.....** at New Delhi

(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

etc
A

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, P.S.M. Public School, Pratap Vihar, Kirari Extn. Nangloi, Delhi-86.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : P.S.M. Public School, Pratap Vihar, Kirari Extn. Nangloi, Delhi-86.
2. Type of Occupancy : Educational (**Ground + 2 upper floor**)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2018/WZ/704 dated 13.04.2018
5. Fire Safety directives letter No : DOE Circular dated 01.03.2011
6. Date of inspection : 22.11.2021
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Sh. Deepak (Chairman)
9. Year of Construction : 1978
10. Applicant's letter No. : Online e-mail Dated 27.09.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible 4.5m NA 	<ul style="list-style-type: none"> Accessible On road NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> 04 NA 	<ul style="list-style-type: none"> 04 NA 	<ul style="list-style-type: none"> MR NA
	e. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<ul style="list-style-type: none"> 1.5m NA 	<ul style="list-style-type: none"> 1.80, 1.10 & 1 x 2 NA 	<ul style="list-style-type: none"> MR(Old case) NA
	f. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.5m	2.40m	MR
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> 30 a/c per hour 12 a/c per hour 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 10nos. ABC/CO2 ISI marked 	<ul style="list-style-type: none"> 15nos. ABC/CO2 Yes 	<ul style="list-style-type: none"> MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<ul style="list-style-type: none"> 02 30mm 5m 	<ul style="list-style-type: none"> 02 Provided Provided 	<ul style="list-style-type: none"> MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power 	<ul style="list-style-type: none"> NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA

	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 & 180lpm	450 & 180lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

N/28

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in **Director of Education Circular**, and removal of shortcomings issued vide letter no. 446 dated 01.09.2021, the FSC issued vide letter no. F.6/DFS/MS/School/2018/WZ/704 dated 13.04.2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO (Rohini)**

DO (NW)

~~DCFO (W2)~~

AA of Rohini

FI letter is put up for kind perusal and signature please.

~~DCFO (W2)~~

MS/ all