

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI**

No. F6/DFS/MS/MN/Metro/2021

1602

Dated: 02/12/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Punjabi Bagh Metro Station line No. 05** located at **Punjabi Bagh, Ring Road, Inderlok--Mundka line New Delhi**, comprised of **Ground + Concourse & Platform**, was issued FSC vide Letter No. **F6/DFS/MS/2010/824** dated **18/03/2010**. The premises was re inspected by the officer concerned of this department on 16/11/2021 in the presence of **Sh. Sanyam Jain (AM/Fire)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D sub Division D- with effect from 02/12/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/12/2021..... at New Delhi by.

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to: -

1. Sh. Vivek Srivastava (JGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations/ Addition & Alteration w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Punjabi Bagh Metro Station Line No. 05 Located at Punjabi Bagh, Ring Road, Inderlok – Mundka line, New delhi-110026
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2010/824 dated 18/03/2010
5. Fire Safety directives letter No : F6/DFS/MS/BP/2008/294 dated 06/02/2008
6. Date of inspection : 16/11/2021
7. Name of the Inspecting Officers : Sarabjeet Singh (ADO MN)
8. Name and designation of officers from the building side : Sh. Sanyam Jain(AM/Fire)
9. Year of Construction : 2010
10. Applicant's letter No. : E-Mail dated - 03/09/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09 mts	Provided	MR
	• Gate width	05 mts	Provided	MR
	• Width of internal road	NA	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases		Provided	MR
	• Upper Floors	02 (G to Con.) + 04 (Con. to PF)		
	• Basements	NA	NA	NA
	b. Width of staircases		Provided	MR
	• Upper Floors	2 x 2 mts (G to Con.) 2 x 4mts (Con. to PF)		
	• Basements	2x2 mts (Con. to PF)	NA	NA
	c. Protection of exits		Required	MR
	• Fire check door		Provided	MR
	• Pressurization		NA	NA
	e. No. of continuous staircases to terrace		Required	MR
	f. Width of Corridor		433 cm	MR
	g. Door Size		2 m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	@ 1 for 300 m <sup>2</sup> , CO2 & WCO2	Provided	MR
	• Types	Required	Provided	MR
	• IS marking		Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	2 (At Each PF)	Provided	MR
	• Length of hose reel hose	45m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	<b>MOEFA</b>	Smoke	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	02	Provided	MR
	• Hose Box	Required	Provided	MR
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	1800 lpm	Provided	MR
	➤ Head of Main pump	60m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	1800 lpm	Provided	MR
	➤ Standby Pump Head	60m	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	50,000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	NA	NA	NA
15	<b>Exit Signage.</b>	Required	Provided	MR





~16



16	<b>Provision of Lifts.</b>			NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	MR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	
18	<b>Refuge Area.</b>			NA
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	
19	<b>Fire Control Room</b>			MR
	• Detector System Panel	Required	Provided	NA
	• Flow Switch Panel	NA	NA	MR
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	NA
	• Building Floor Plans	NA	NA	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	NOVEC 1230 Flooding for ASS, HT,LT Pannel	Provided	


The fire protection systems provided in the Building were test checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of fire safety certificate is issued vide letter no. F6/DFS/MS/MS2010/824 dated 18/03/2010 is recommended.


  
 Signature of the Inspecting Officer  
 Name: Sarabjeet Singh  
 Designation: ADO (MN)


  
 29/11/2021  
 22/11/2021


30/11/2021  
  
 23/11/2021  
  
 25/11/2021

  
 M. N

Sir, F.T is put up for your personal & Signature please,

  
 29/11/2021

  
 27/11/2021

  
 29/11/2021