

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021 / School / WZ / 968



Dated: 1/12/21

FIRE SAFETY CERTIFICATE

Certified that **Sarvodaya Vidyalaya** located at **Auchandi, Delhi-110039** comprised of **02 Blocks (Ground Floor only)** owned/occupied by **Sarvodaya Vidyalaya** was issued FSC by this department vide letter No F6/DFS/MS/School/2018/2581 dated 30.11.2018. The premises was inspected by the officer concerned of this department on 23.11.2021 in the presence of **Sh. Rajesh (Estate Manager)**, and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/premise is fit for occupancy **Group B Educational (School)** with effect from1.12.21..... for a period of three years and subject to compliance of the conditions mentioned below.

Issued on 1.12.21..... at New Delhi

Yours faithfully


(Dharampal Bhardwaj)
Dy. CHIEF FIRE OFFICER
WEST ZONE


Copy to :-

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Sarvodaya Vidyalaya, Auchandi, Delhi-39.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

N-1

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Vidyalaya, Auchandi , Delhi-110039.
2. Type of Occupancy : Educational
3. Building Comprised : Two Blocks-(Ground Floor Only).
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No. F.6/DFS/MS/School/2018/2581 Dated-30/11/2018
6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
7. Date of inspection : 23 /11/2021
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers
From the building side : Sh. Rajesh (Estate Manager)
10. Year of Construction : 2011 & 2012
11. Applicant's letter No. : E Mail ID , Dated-12/11/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width 	6.0 m	6.0 m	MR
	<ul style="list-style-type: none"> • Gate width 	4.5 m	4.5 m	MR
	<ul style="list-style-type: none"> • Width of internal road 	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor • Basements 	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	1.00 m Double Door	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
		NA	NA	NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	NA	NA

R

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	08	12	MR
	<ul style="list-style-type: none"> Types 	ABC	ABC/Co2	MR
	<ul style="list-style-type: none"> IS marking 	Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA

On

	➤ Pump House Access	NA	NA	NA
	• Terrace level	-	-	-
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
		-	-	-
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Pa

--	--	--	--	--

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01.03.2011 it is recommended to renew the Fire Safety Certificate issued vide letter no.F-6/DFS/MS/School/2018/2581.

~~DO (W)~~

~~ADDO (W)~~
24/11/2021

~~DeFO (W)~~

~~ADDO (W)~~
24/11/2021

~~ADDO (B.W)~~
24/11/21

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

~~ADDO (B.W)~~ F-T letter in Purup for signature

~~DeFO (W)~~

~~ADDO (W)~~
24/11/2021

~~ADDO (B.W)~~
24/11/21

ms/ all