

C-34

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001**

No.F.6/DFS/MS/School/2021/SZ/ 992

Dated: 7/12/21

FIRE SAFETY CERTIFICATE

Certified that the **Aryaman Public School**, RZ-127, West Krishna Vihar, Gopal Nagar, Najafgarh, New Delhi-110043 comprised of ground floor plus two upper floors, owned/occupied by Aryaman Public School was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2018/SZ/2369 dated 22/10/2018. The School building was re-inspected by the officer concerned of this department on 27/11/2021 in the presence of Sh. Amarjeet Singh (Owner) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....7/12/21..... at New Delhi.


(SUNIL CHAWDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Principal,
Aryaman Public School, RZ-127,
West Krishna Vihar, Gopal Nagar, Najafgarh, New Delhi-110043
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. There shall not be more than 45 children in the classrooms having single door.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Aryaman Public School, RZ-127, West Krishna Vihar, Gopal Nagar, Najafgarh, New Delhi-110043.
2. Building is comprised of : Ground plus two upper floors only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : 1.6/DFS/MS/School/2018/SZ/2369 dated 22/10/2018
6. Fire Safety directives letter No : N/A
7. Date of inspection : 27/11/2021
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Amarjeet Singh (Owner)
10. Year of Construction : 2006 (GF & FF) & 2016-17 (SF)
11. Applicant's letter No. : Outdoor diary no. 3763 dated 29/10/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL-16 requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 m 4.5 m N/A	Provided Directly accessible from road N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 No.'s	02 No.'s	M/R
	<ul style="list-style-type: none"> • Upper Floors • Basements 	N/A	N/A	N/A
	b. Width of staircases	1.50 m	1.50 m	M/R
	<ul style="list-style-type: none"> • Upper Floor • Basements 	N/A	(02 no.'s) N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required 1.50 m	Provided 2.60 m	M/R M/R
	e. Width of Corridor	1.0 m & 1.20 m	.90/1.05 m &	M/R, being old
	f. Class Room Door Size	on SF	1.20 m on SF	case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	07 no's ABC/CO ₂ type	Provided Provided	MR MR
		ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 no. 30 m 5 mm	Provided Provided Provided	MR MR MR

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Stand by Pump out put	N/A	N/A	N/A
	➤ Stand by Pump Head	N/A	N/A	N/A
	➤ Auto starting/Manual Stopping	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	• Pump House Access			
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	30 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltrs	Provided	MR

N/20

		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.		No Lift	
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• P.A System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number E.6/DPS MS School/2018/SZ/2369 dated 22/10/2018 renewal under rule 35 of the Delhi Fire Service Rules - 2010 is recommended.

R. K. Yadav
29/11/2021

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South West) *R. K. Yadav*
30/11/2021

Dy Cro/1523
dh
30/11

F T letter
Dy Cro/1523
dh

A DO put up for your please
M.S. CC
R. K. Yadav
31/12/2021