

C-15

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F-6/DFS/MS/SZ/2021/ 359

Dated: 09/12/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **M/S Duty free (A unit of Dream Bar Pvt Ltd)** Located at **Shop No. R-03, 5<sup>th</sup> Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110078**, in a building comprised of four tier Basement + Ground + 05 Upper Floors ( FSC issued to mall vide letter noF6/DFS/MS/Mercantile/2019/SZ/1972 dated- 16/10/2019 owned/ occupied By **Duty free (A unit of Dream Bar Pvt Ltd)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 23/11/2021 in the presence of Mr. Hament puri (Employee) and found that the said building that the premises is fit for occupancy class " Assembly" Group D with effect from 09/12/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...09/12/21 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1<sup>st</sup> Floor, PS, Defence Colony, N Delhi.
2. The Manager, M/S Duty free (A unit of Dream Bar Pvt Ltd) Located at Shop No. R-03 5<sup>th</sup> Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110078.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building: **M/S Duty free (A unit of Dream Bar Pvt Ltd) Located at Shop No. R-03, 5<sup>th</sup> Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110078.**
2. Type of Occupancy : **Class-D (Assembly)( At Fifth Floor in the Mall)**
3. Type of Case : **New**
4. Details of previous NOC : **F6/DFS/MS/Mercantile/2019/SZ/1972 Dated 16/10/2019(issued to mall)**
5. Fire Safety directives Letter No. : **F6/DFS/MS/BP/2016/326 Dated 16/12/2016(issued to mall)**
6. Date of inspection : **23/11/2021**
7. Name of the Inspecting Officer ; **ADO (DWK)**
8. Name and designation of Officer  
from the building side : **Mr. Hament puri (Employee)**
9. Year of Construction : **2019**
10. Applicant's letter No. : **2020110225683 Dated-09/11/2021**

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtrs	Provided	MR
	• Gate width	06mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits( <b>Common With Mall</b> )			
	a. Number of staircases			
	• Upper floors	2	03 Provided (by Mall)	MR
	• Basements	NA	12 Provided by Mall	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided by Mall	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	NA	Provided	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	2x 1.5 M	<b>Provided ( including door frame)</b>	<b>MR</b>
3.	Compartmentation( <b>Common With Mall</b> )			
	• Fire check door	NA	Provided by Mall	NA
	• Sealing of electrical shafts	NA	Provided by Mall	NA
	• Fire Rating of shaft door	NA	Provided by Mall	NA
	• Water Curtain	NA	Provided by Mall	NA
	• Fire Dampers	NA	Provided by Mall	NA

4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA	NA	NA
		12 a/c per hour	Provided by Mall	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	03 nos. each type, ABC, CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reel	<b>Common with mall</b>		
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	Required	Provided by Mall	MR
		36 m	Provided by Mall	MR
		5 mm	Provided by Mall	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke/ Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided by Mall	MR
10.	Automatic Sprinkler System ( <b>Common with mall</b> )			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	Provided	NA
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants: ( <b>common with the mall</b> )			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150 mm	Provided by Mall	MR
		1	3 Provided by Mall	MR
		Required	Provided by Mall	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	Provided by Mall	NA
		NA	Provided by Mall	NA
13.	Pumping Arrangements: <b>Common with Mall</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	2280 lpm	2850 LPM Provided By Mall	MR
		120 mtr	120 mtr Provided By Mall	MR
		01	2 electric Provided By Mall	MR
		180 lpm	180 LPM 2 Nos+Water Curtain Pump 2280 LPM Provided By Mall	MR
		120 mtr	120 mtr+Water Curtain 60 mtrs Provided By Mall	MR
		2280 lpm	2850 LPM Provided By Mall	MR
		120 mtr	120mtr Provided By Mall	MR
		Required	Provided By Mall	MR
		Required	Provided By Mall	MR
		900lpm	Provided By Mall	MR
		40 m	Provided By Mall	MR
		Required	Provided By Mall	MR
		Required	Provided By Mall	MR

14.	Captive water Storage for fire fighting: <b>Common with Mall</b>			
	• Under ground tank capacity	1,50,000	400000 l ( By Mall)	NA
	➤ Draw off connection	Required	Provided By Mall	NA
	➤ Fire service inlet	Required	Provided By Mall	NA
	➤ Access to tank	Required	Provided By Mall	NA
	• Overhead Tank capacity	10, 000 litres	Provided By Mall	MR
15	Exit Signage	Required	Provided By Mall	MR
16.	Provision of Lifts <b>Common with Mall</b>			
	➤ Pressurization of Lift Shaft	NA	Provided By Mall	NA
	➤ Pressurization of lift lobby	NA	Provided By Mall	NA
	➤ Communication in lift Car	NA	Provided By Mall	NA
	➤ Fireman's Grounding Switch	NA	Provided By Mall	NA
	➤ Lift Signage	NA	Provided By Mall	NA
17.	Standby power supply	Required	Provided By Mall	MR
18.	Refuge Area			
	➤ Total area	NA	Provided	NA
	➤ Location	NA	Provided	NA
19.	Fire control room <b>(Common with Mall)</b>			
	➤ Detector system panel	NA	Provided By Mall	NA
	➤ Flow Switch Panel	NA	Provided By Mall	NA
	➤ PA System Panel	NA	Provided By Mall	NA
	➤ Battery backup	NA	Provided By Mall	NA
	➤ Building Floor Plans	NA	Provided By Mall	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers .....**NIL**.....

Note-

1. M/S Duty free (A unit of Dream Bar Pvt Ltd) Located at Shop No. R-03 5<sup>th</sup> Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110078.
2. As per plan submitted by the applicant the area of the restaurant is 257 m<sup>2</sup>
3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 143 (257/1.8=142.7 say 143) for whole restaurant.
4. The total seating capacity comes out be 143.

Signature of the Inspecting Officer  
Name Sh. Udai vir Singh  
Designation ADO/DWK

DOS/DW

25/11/2021

Dy CEO (S2)

2/12

C. F. O.

Handwritten signatures and initials at the bottom of the page.

Handwritten signature at the bottom right of the page.

