

C-20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2021/SZ/ 991

Dated: 7/12/21

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C Primary School**, Ghasi Pura I/II, New Delhi-110043 comprised of Ground plus two upper floors owned occupied by S.D.M.C was issued FSC by this department vide letter no. F.6/DFS/MS/School/2018/SZ/1395 dated 14/06/2018. The school building was re-inspected by the officer concerned of this department on 27/11/2021 in the presence of Smt. Manjeet Devi (Principal) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....7/12/21..... at New Delhi.



(SUNIL CHAWDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Principal,
S.D.M.C Primary School,
Ghasi Pura I/II, New Delhi-110043.
2. Director of Education,
S.D.M.C, Civic Centre,
Minto Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : S.D.M.C Primary School, Ghasi Pura I/II, New Delhi-110043
 2. Building is comprised of : Ground plus two upper floors.
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : F.6/DFS/MS/School/2018/SZ/1395 dated 14/06/2018
 6. Fire Safety directives letter No : N/A
 7. Date of inspection : 27/11/2021
 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
 9. Name and designation of officers
 From the building side : Smt. Manjeet Devi (Principal)
 10. Year of Construction : 2012-2013
 11. Applicant's letter No. : Nil dated 28/10/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 14.06.2018	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 m 4.5 m NA	Provided Directly accessible from road NA	M/R MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 No's	Provided	M/R
	<ul style="list-style-type: none"> Upper floors Basements 	N/A	N/A	N/A
	b. Width of staircases	1.50 m	1.50 & 1.30 m	M/R, being old case
	<ul style="list-style-type: none"> Upper Floor Basements 			
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.50 m	1.70-1.80 m	M/R
	f. Door Size	1.0 m	1.0 m (Double door)	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire chees door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A	N/A	N/A
		Required	Natural Ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	07 no's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	M/R M/R M/R

N/24

15.	6.	First-Aid Hose Reels			
16.		<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 m 05 mm	Provided Provided Provided	M/R M/R M/R
7.	7.	Automatic fire detection and alarming system			
8.		<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
	8.	MOEFA	N/A	N/A	N/A
	9.	Public Address System	N/A	Provided	M/R
	10.	Automatic Sprinkler System			
		<ul style="list-style-type: none"> Basement Ground floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	M/R N/A N/A
	11.	Internal Hydrants			
		<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	Provided 100 mm Provided One Provided	M/R M/R M/R
	12.	Yard Hydrants			
Sj		<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
sp	13.	Pumping Arrangements			
7		<ul style="list-style-type: none"> Ground level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A
tl		<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto starting of pump 	N/A N/A 450 LPM 40 m Required Required	N/A N/A Provided Provided Provided Provided	N/A N/A M/R M/R M/R M/R
sz	14.	Captive Water Storage for fire fighting			
F.		<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 10,000 ltrs.	N/A N/A Provided N/A Provided	N/A N/A N/A N/A M/R
Sc					

Divi

N/25

		Required	Provided	M/R
15.	Exit Signage.			
16.	Provision of Lifts.			(No Lift)
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS School/2018/SZ/1395 dated 14/06/2018 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

R. K. Yadav
 29/11/2021

Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - Asstt. Divisional Officer

Divisional Officer (South West)

By cfo /s/23

30/11/2021
fc
30/11

A. D. J. K. P.