

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/Bnqt/2021/NDZ/ 02

Dated: 06/12/2021

FIRE SAFETY CERTIFICATE

Certified that the Shree Shyam Palace (Banquet Hall) located at PD area of Mansarovar Park Metro Station, Shahdara, Delhi-110032, comprised of ground plus two upper floor owned/occupied by AVG Logistic Pvt. Ltd. was issued FSC vide letter No-F6/DFS/MS/Bnqt/2019/NDZ/1911 dated- 07/10/19 (Ground floor). The premises was inspected by the officer concerned of this department in the presence of Sh. Sanjay Aggarwal, owner and found that the building have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the banquet hall building is fit for ground plus one upper floor occupancy class "D" 'Assembly Building' (Banquet Hall) Ground plus one floor with effect from 06/12/2021 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....06/12/2021.....at New Delhi by

(Atul Garg)
Director

Delhi Fire Service

To,

Sh. Sanjay Aggarwal,
M/s Shree Shyam Palace (Banquet Hall)
PD Area at Mansarovar Park Metro Station,
Shahdara, Delhi-110032

Application ID No.-2021020310109

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : M/s Shree Shyam Palace banquet Hall
PD Area at Mansarovar Park Metro Station,
Shadhara , Delhi-110032
2. Building is comprised of : Ground plus two upper floors
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Addition/Alteration
5. Details of Previous NOC letter : F6/DFS/Ms/Bnqt/2019/NDZ/1911 dt 07/10/19 (For G Floor)
6. Fire Safety directive letter No Nil
7. Date of Inspection : 10/03/2021 & 21/06/2021
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer from the building side : Sh. Sanjay Aggarwal (Owner)
10. Year of Construction : 2019 & 2020
11. Applicant's letter No : 2021020310109 dated 05/02/21

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	09 mtr.	28 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	02 nos	03 nos	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	02 mtr	02 mtr, 02 mtr, & 1.70 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	02 mtr	02 mtr	MR
	f. No. of Doors	04 nos.	07 nos.	MR
	g. Door Size	02 mtr.	02 mtr, 02 mtr, 02 mtr, 02 mtr, 1.50 mtr, 1.50mtr, 1.17 mtr, 1.17 mtr, 1.13 mtr,	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
		N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	16 nos.	22 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			

	Total numbers on each floor	04 No.	04 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter's location	Different Location	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	MR
	• sprinkler above false ceiling	N/A	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	02 no	02 no	MR
	• Hose Box	02 no	02 no	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	Provided for entire metro building		
	• Ground Level			
	➤ Discharge of main Pump	N/A	1800 lpm	MR
	➤ Head of Main Pump	N/A	70 mtrs	MR
	➤ Number of main pumps	N/A	01 nos	MR
	➤ Jockey pump out put	N/A	225 lpm	MR
	➤ Jockey pump head	N/A	70 mtr	MR
	➤ Standby pump out put	N/A	1800 lpm	MR
	➤ Standby pump Head	N/A	70 mtrs	MR
	➤ Auto Starting /Manual stopping	N/A	Provided	MR
	➤ Pump House Access	N/A	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	900 Lpm.	900 Lpm.	MR
	➤ Head of the Pump	60 mtr	60 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	1,00,000 Ltrs.	MR
	➤ Draw-off connection	N/A	Provided	MR
	➤ Fire service inlet	N/A	Provided	MR
	➤ Access to tank	N/A	Provided	MR
	• Overhead Tank capacity	25,000 Ltrs.	25,000 Ltrs.	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rule, it is recommended to issue Fire Safety Certificate.

Mehmood
22/06/2021

Signature of the Inspecting Officer
Name : Mehmood
Designation : ADO (TP)

Ayub (ADP)

Please reverify Pt. no. 14 (Lift Bank) capacity from DMPL.

Mehmood
30/6/21

ADO (TP)

Spoken directly GEF is ISSUED
NOC now. he asking the OF
requiring NOC, the OF
tand 28/12/04

Mehmood
13/7/2021

ADO (TP)

Ayub (ADP)

Mehmood
14/7/21

CFO (ADP) - D/177

Director

Mehmood
19/07/2021

Kindly see letter 15/12/2020
No 906/

Mehmood

Mehmood
12/7/21

ADO (TP)

