

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/2021/SZ / 1002

Dated: 10/12/21

FIRE SAFETY CERTIFICATE

Certified that the **J.B.M Public school** running at ground plus two upper floors in a building comprised of ground plus three upper floors located at Nasir Pur New Delhi-110045 owned/occupied by J.B.M Public school was issued FSC vide letter no. F6/DFS/MS/School/2018/SZ/2627 dated 06/12/2018. The school building was re-inspected by the officer concerned of this department on dated 06/12/2021 in the presence of Dr. Amit Solanki (Manager). The building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 issued by Directorate of Education, Govt.of NCT of Delhi, and found that the building (GF, FF & SF) is fit for occupancy class B 'Educational Building' with effect from10/12/21. for a period of three years, subject to conditions printed overleaf.

Issued on.....10/12/21.....at New Delhi by

(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to:-

1. The principal, J.B.M Public School, Nasir Pur, New Delhi-110045.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

M/15

INSPECTION REPORT

- 1 Name & address of the building : J.B.M Public school, Nasir Pur, New Delhi-110045.
 2. Building is comprised of : Ground plus three upper floors but school running at ground plus two upper floor.
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : F.6/DFS/MS/school/2018/SZ/2627 Dt.- 06/12/2018 (G+2)
 6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011
 7. Date of Inspection : 06/12/2021
 8. Name of the Inspecting Officers: : ADO R.K. YADAV
 9. Name of the designation of Officer from the building side : Dr. Amit Solanki (Manager)
 10. Year of Construction : 2002 & 2015
 11. Applicant's letter No : Outdoor diary 4410 Dated -18/11/2021

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	DOE 1.3.2011	Dated	Provided at Site	Remarks MR/NMR
1	Access to building				
	Road width	6 m		06 m	MR
	Gate width	4.5 m		Direct accessible from road	MR
	Width of internal road	N.A.		N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits				
	a. Number of Staircases				
	Upper Floor	04 No.s		04 Nos.	MR
	Basement	N.A.		N.A.	N.A.
	B. Width of Staircases				
	Upper Floor	1.5 m & .75 m		2 nos. 1.25 m each 1 no. 1.20 m & 1 no. 1.40 m + 1 Ramp (1.5 m) G to 1 st Floor.	MR
	Basement	N.A.		N.A.	N.A.
	c. Protection of exits				
	Fire check door	N.A.		N.A.	N.A.
	Pressurization	N.A.		N.A.	N.A.
	e. No. of continuous staircases to terrace	2 no.		2 no.	MR
g. Width of Corridor	1.5 m		1.50 m	MR	
h. Door Size	1 m		Provided	MR	
3	Compartmentation.				
	Fire check door	N.A.		N.A.	N.A.
	Sealing of electrical shafts	N.A.		N.A.	N.A.
	Fire rating of shaft door	N.A.		N.A.	N.A.
	Water curtain	N.A.		N.A.	N.A.
	Fire Dampers	N.A.		N.A.	N.A.
4	Smoke Management System.				
	Basement	N.A.		N.A.	N.A.
	Upper floor	Required		Natural ventilation	MR

5.	Fire Extinguisher			
	Total numbers	10 Nos.	12 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
1.	Total numbers of each floor	01 no.	Two	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants per floor	One	Two	MR
	Hose Box	N.A.	one	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

W/17

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.6/DFS/MS/school/2018/SZ/2627 Dt.- 06/12/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

R K YADAV
07/12/2021

Signature of the Inspecting Officer
Name R K YADAV
Designation ADO (JKP)

DO (South West)

By [Signature] 07/12/2021

By [Signature] / SZ

[Signature]
a/p/c

ADO (JKP)

FT holder as per up for signature please