

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

45

No. E.6/DFS/MS/EH/2021/SZ/ 365

Dated: 10 / 12 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the name & style of **M/s Misosexy** (A Unit of Misosexy Ventures LLP) at Plot No H 5 oblique 3 and 4, **Front side Second Floor**, Ward No - 1, Ambawatta One, Kalka Das Marg, Mehrauli, New Delhi-110030 in the building comprised of Basement, Ground, plus Two Upper floor owned/occupied by Mr. Neeraj Jain (owner) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 06/12/2021 in the presence of Mr. Puneet Kumar and that the premise is fit for occupancy class **Group-D Assembly (Restaurant running at Front side Second Floor only)** with effect from 10 / 12 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 10 / 12 / 2021 at New Delhi by

(ATUL GARG)  
DIRECTOR / DFS

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID 2021120227710 dated 04-12-2021)
3. M/s Misosexy (A Unit of Misosexy Ventures LLP) at Plot No H 5 oblique 3 and 4, Front side Second Floor, Ward No -1, Ambawatta One, Kalka Das Marg, Mehrauli, New Delhi-110030

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

### INSPECTION REPORT

1	Name & Address of the Building	M/s Misosexy (A Unit of Misosexy Ventures LLP) at Plot No H 5 oblique 3 and 4, Front side Second Floor, Ward No -1, Ambawatta One, Kalka Das Marg, Mehrauli, New Delhi-110030		
2	Type of Occupancy	Assembly 'Group-D' (Restaurant running at 2 <sup>nd</sup> Floor only)		
3	Building comprised of	Basement Ground plus Two upper floors		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	UBBL 2016/ NBC Part IV		
7	Date of Inspection	07.12.2021		
8	Name of the Inspecting Officers	Rajesh Kumar/ ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Puneet Kumar		
10	Year of construction/ date of conversion	2000		
11	Applicant letter No.	MHA Portal ID 2021120227710 dated 04-12-2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/ NBC Requirement	Provided at Site	Remarks
1	<b>Access to Building.</b>			
	• Road width	06m	12m	MR
	• Gate width	NA	NA	-NA-
	• Width of internal road	NA	NA	-NA-
2	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a. Number of Staircase</b>			
	• Upper floors	02 Nos	02 no's	MR
	• Basement floor	-NA-	NA	-NA-
	<b>b. Width of Staircase</b>			
	• Upper floors	1.50m each	2m & 1.50 m	MR
	• Basement floor	-NA-	NA	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	NA	NA	NA
	• Pressurization	-NA-	NA	-NA-
	<b>d. No. of continuous staircase to terrace</b>	02	02	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	2 Exits 1.5m each	1.50 m each	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Natural ventilation	MR
5	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	10 Provided	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			

	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooper's location</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		N/A	NA	N/A
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	NA	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	Required	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	Common with Building		
	<ul style="list-style-type: none"> <li>Discharge of main pump.</li> </ul>	2280lpm	Provided	MR
	<ul style="list-style-type: none"> <li>Head of main pump.</li> </ul>	40m	Provided	MR
	<ul style="list-style-type: none"> <li>Number of main pumps.</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>Jockey Pump output.</li> </ul>	180 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>Jockey Pump head.</li> </ul>	40m	Provided	MR
	<ul style="list-style-type: none"> <li>Standby Pump output.</li> </ul>	2280lpm	Provided	MR
	<ul style="list-style-type: none"> <li>Standby Pump head.</li> </ul>	40m	Provided	MR
	<ul style="list-style-type: none"> <li>Auto Starting / Manual Stopping.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace Level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of pump.</li> </ul>	900 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>Head of pump.</li> </ul>	40m	Provided	MR
	<ul style="list-style-type: none"> <li>Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Auto starting of pump.</li> </ul>	Required	Provided	MR
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	1,00,000 ltrs	Provided	MR
	<ul style="list-style-type: none"> <li>Draw-off connection.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Fire Service Inlet.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Access to tank.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	20,000 Ltrs	20,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	-NA-	-NA-	-NA-



19	<ul style="list-style-type: none"> <li>• Location</li> </ul> <b>Fire Control Room.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Detector System Panel.</li> <li>• Flow Switch Panel.</li> <li>• PA system Panel.</li> <li>• Battery backup</li> <li>• Building floor plan</li> </ul>	-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>	-NA-	-NA-	-NA-

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

*RK*  
08/11/2021

Signature of the Inspecting Officer  
Name: Rajesh Kumar  
Designation: ADO / BCP

DO (SD)

*RK*  
08/11/21

DCFO (S2)

*[Signature]*  
09/12

C.F.O. (D. off)

~~Director (M)~~  
10/11/21

~~DLFO (S2)~~ RT PL

Any BCP  
F.t. letter is put up for signature, please.

~~Director (M)~~  
10/11/21

*[Signature]*