

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Club/2021/SZ/ 615

Dated: 10/12/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s **Palika Services Officers Institute** located at Vinay Marg, Chanakyapuri, New Delhi-110021, comprised of lower ground and upper ground floor only owned / occupied by New Delhi Municipal Council was issued FSC by this office vide letter No. F6/DFS/MS/Club/2019/SZ/48 Dated 08/01/2019. The premises was re-inspected by the officer concerned of this department on 30/11/2021 in the presence of Mr. Narender Gaur (Fire Officer) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Assembly" (Group-D) with effect from 10/12/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 10/12/2021 at New Delhi.



(SUNIL CHAUDHARY)

DY. CHIEF FIRE OFFICER (SZ).

Copy to :-



1. Sh. Narender Gaur, Fire Officer, New Delhi Municipal Council, Palika Kendra, New Delhi-110001.
2. Authorized Signatory, M/s Palika Services Officers Institute, Vinay Marg, Chanakyapuri, New Delhi-110021.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

21-21
2/19

INSPECTION REPORT

1. Name & address of the building: M/s Palika Services Officers Institute, Vinay Marg, Chanakyapuri, New Delhi-110021.
2. Type of Occupancy : Club Building (Eating House & Sports Facility)
3. Building Comprised of : Two Stories (Lower Ground & Upper Ground).
Both floors are ground floor on either of the side.
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/Club/2019/SZ/48 Dated 08/01/2019
6. Fire Safety directives Letter No. : Nil
7. Date of inspection : 30/11/2021
8. Name of the Inspecting Officer : A.K. Jaiswal (A.D.O. S.J)
9. Name and designation of Officer from the building side : Sh. Narender Gaur (Fire Officer)
10. Year of Construction : 2005
11. Applicant's letter received through MHA portal No.: 20211019224546 dated 19/10/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtrs	9 mtr	MR
	• Gate width	5 mtrs	Provided	MR
	• Width of internal road	NR	NR	NR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3	MR
	• Basements	NR	NR	NR
	b. Width of staircases			
	• Upper floors	2 mtr	2 m, 1.3m & 0.80m	MR (Old Case)
	• Basements	NR	NR	NR
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NR	NR	NR
	f. Door Size	1.50 mtr	1.50m x 2	MR
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	NR	NR	NR
	• Upper floors	12 ACPH	Exhaust Fan Provided	MR
5.	Fire Extinguishers			
	• Total numbers	8	Provided	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR

a/j-20

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30Mtr.	30Mtr.	MR
	• Nozzle diameter	5mm.	5mm.	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR

8.	MOEFA	Required	Provided	MR
----	-------	----------	----------	----

9.	Public Address System	NR	NR	NR
----	-----------------------	----	----	----

10.	Automatic Sprinkler System			
	• Basements	NR	NR	NR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR

11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR

12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR

13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450 LPM	450LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	10,000 lts.	10,000 lts.	MR

21-21


15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	NR	NR	
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Club/2019/SZ/48 Dated 08/01/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Do (S) on leave
Dy CFO/SZ


F.F.



A.K. Jaiswal
21/2/2021

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : A.D.O. (S.J.)

~~ADD/SJ~~
Dy CFO/SZ



F.T. is added for sign. pl.

AB
7/12/2021

on-5 cell