

C-38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No.F.6/DFS/MS/School/2021/ 999

Dated: 10/12/21

FIRE SAFETY CERTIFICATE

Certified that the building of Sarvodaya Kanya Vidyalaya at Matiala, New Delhi-110059 is having three blocks Main block ground plus three, Pry Block ground plus one & SPS Block ground plus three upper floors. SPS block was issued Fire Safety Certificate by this department vide letter NO. F6/DFS/MS/School/2017/1484 dated 12/10/2017. The School building was re- inspected by the officer concerned of this department on 30/11/2021 in the presence of Sh. Dubey (Estate Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....10/12/21..... at New Delhi.


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Principal,
Sarvodaya Kanya Vidyalaya, SPS Block, Matiala, New Delhi-110059.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1720
INSPECTION REPORT

1. Name & address of the building: Sarvodaya Kanya Vidyalaya, at Matiala, New Delhi-110059.
 2. Building is comprised of : 3 blocks (Main block =G+3, Pry Block =G+1 & SPS Block=- G+3 upper floors)
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : F6/DFS/MS/School/2017/SZ/1484 dated 12/10/2017
 6. Fire Safety directives letter No : N/A
 7. Date of inspection : 30/11/2021
 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
 9. Name and designation of officers
 From the building side : Sh. Dubey (Estate Manager)
 10. Year of Construction : 2016-17
 11. Applicant's letter No. : GSKV/Mat/2021/4629 dated 01/11/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	10 mtrs 06 mtrs N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Main block SPS block Pry. block 	02 No. 1 No. 2 No.	02 No. 1 No. 2 No.	M/R M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Main block SPS block Pry. block 	1.50 m 1.50 m 1.50 m	1.30 & 1.40 m 1.72 m 1.40 & 1.46 m	M/R M/R M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	M/R
	e. Width of Corridor	1.50 m	1.50/1.80 m	M/R
	f. Door Size	1.0 m	1.0 m & 1.20m (Double door)	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R

1720

M/21

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Main & SPS blk Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM each blk 30 mtrs Required Required	N/A 450 LPM Provided Provided Provided Provided	N/A M/R M/R M/R M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity each block 	N/A N/A N/A N/A 10,000 ltrs Required	N/A N/A N/A N/A Provided Provided	N/A N/A N/A N/A M/R M/R
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
17.	Standby power supply	N/A	N/A	N/A

N/22

18.	Refuge Area. <ul style="list-style-type: none"> > Total Area > Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter no. F.6/DFS/MS/School/2020/SZ654 dated 30/09/2020 has been complied.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

R.K. Yadav
 21/12/2021

Signature of Inspecting Officer
 Name:- R.K. Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

[Signature]
 02/12/2021
 Dy CFO (S2)

F.T.
[Signature]
 3/12

A.O. (S2)

FT letter is put up for sign. please

[Signature]
 Dy CFO (S2)

M-S. Cell

R.K. Yadav
 7/12/2021