

c-76

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/EH/2021/SZ/ 362

Dated: 10/12/21

FIRE SAFETY CERTIFICATE

Certified that the M/s Barshala (a unit of Indospirit Bars Pvt. Ltd.), running at first floor only in a building comprised of ground plus one upper floor located at Plot No. 8,9,10, G-8, J-Block, Community Centre, Shop No.59, GF, 125- 129, 151-153 FF, Rajouri Garden, New Delhi-110027, owned/occupied by M/s Barshala (a unit of Indospirit Bars Pvt. Ltd.) was issued FSC by this department vide letter no. F.6/DFS/MS/EH/2018/SZ/2401 dated 25/10/2018. The restaurant building was re-inspected by the officers concerned of this department on 30/11/2021 in the presence of Mr. Himanshu Kapoor and found that the restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (**First Floor Only**) is fit for occupancy class Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....10/12/21..... at New Delhi.



(SUNILCHAWDHARY)
DY.CHIEF FIRE OFFICER



Copy to:-

1. The Manager,
M/s Barshala (a unit of Indospirit Bars Pvt. Ltd.), FF, Plot No. 8,9,10, G-8,
J-Block, Community Centre, Shop No.59, GF, 125- 129, 151-153 FF,
Rajouri Garden, New Delhi-110027
2. The Addl. Commissioner of Police,
Licensing Unit, First Floor, Police Station,
Defence Colony, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s Barshala (a unit of Indospirit Bars Pvt. Ltd.), FF, Plot No. 8,9,10, G-8, J-Block, Community Centre, Shop No.59, GF, 125-129, 151-153 FF, Rajouri Garden, New Delhi-110027
2. Building is comprised of : G+1 but restaurant is running at first floor only)
3. Type of Occupancy : Group D (Assembly Building)
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/EH/2018/SZ/2401 dated 25/10/2018
6. Fire Safety directives letter No : N/A
7. Date of inspection : 30/11/2021
8. Name of Inspecting Officers : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Mr. Himanshu Kapoor
10. Year of Construction : Before 2008
11. Applicant's letter No. : Nil dated 13/10/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible (09 m) 4.5 m N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No.'s N/A	Provided N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	Two N/A	1.50, 1.37 & 1.25 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.5 m	Opening in hall	MR
	f. Door Size	Two exits	1.05 m (02 no.'s)	MR old accepted
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 No.'s ABC/ CO ₂ ISI marked	Provided Provided Provided	MR MR MR


6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers 	One	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floor 	N/A	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants 	01 No.	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01 No.	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> Discharge of pump 	40 m	Provided	MR
	<ul style="list-style-type: none"> Head of the pump 	Required	Provided	MR
	<ul style="list-style-type: none"> Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto Starting of pump 	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	5000 ltrs	Provided	MR

N/14


		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			(No Lift)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2018/SZ/2401 dated 25/10/2018 renewal/grant under rule 37 of the Delhi Fire Service rules 2010 is recommended.


 Signature of the Inspecting Officer 02/12/2021
 Name R. K. YADAV
 Designation ADO (JKP)

D.O. (South West)


 Dy CFO (S2)

FF.


 3/12

ADO (JKP)

FT letter is put up for sign please


 Dy CFO (S2)




 7/12/2021