

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/EH/SZ/2021/ 367

Dated: 14/12/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s. Blue Lighting Hospitality Pvt. Ltd., Plot No. 24-B, third floor, Old Rajinder Nagar, Pusa Road, New Delhi-110005, running at third floor of a building comprised of basement, stilt, ground plus three upper floors, owned/occupied by Aman Garg & Sagar Garg have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 10.12.2021 in presence of Mr. Aman Garg (Owner) and the building/premises is fit for occupancy **Class Assembly (Restaurant) Running at Third Floor Only** with effect from 14/12/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 14/12/2021 at New Delhi by.


(Aman Garg)
Director
Delhi Fire Service

Copy to:-

1. The Owner, M/s. Blue Lighting Hospitality Pvt. Ltd., Plot No. 24-B, third floor, Old Rajinder Nagar, Pusa Road, New Delhi - 110005.
2. The Deputy Health Officer, North Delhi Municipal Corporation, Karol Bagh Zone, New Delhi- 110005.
3. The Joint Commissioner of Police (Lic), 1st Floor, Police Station Defence Colony, New Delhi- 110024.

Conditions for the validity of Fire Safety Certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. All the means of escapes /exits shall not be locked/bolted/blocked at any time for safe evacuation of the occupants in case of any emergency.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s. Blue Lighting Hospitality Pvt. Ltd., Plot No. 24-B, third floor, Old Rajinder Nagar, Pusa Road, New Delhi.
2. Building Composition : Basement, stilt, ground plus three upper floors.
3. Type of Occupancy : Assembly (Restaurant), Running at third floor only
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 10.12.2021
8. Name of the Inspecting Officers : Sunil Chaudhary, DCFO(SZ) & P.V. Rathee, ADO (SRD)
9. Name and designation of officers from the building side : Mr. Aman Garg (Director)
9. Year of Construction : 2008
10. Applicant's letter No. : Online application Id 2021111926776 dated 19.11.2021

The said restaurant is running at third floor of a building comprised of basement, stilt, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC/BBL	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02 Nos.	03 Nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	2.0 & 1.50 mts	2.0 mts. (Iron made), GF to FF 1.52 mts, FF to Terrace 1.22 mts. & FF to 3 rd F 1.65-1.74 m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided in kitchen	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	02	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0m & 1.50 m	2.0 mts & 1.70 mts	MR
3	Compartmentation.			
	• Fire check door	Required	Provided in kitchen	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	02 Hrs	Provided	MR
	• Water Curtain	N/A	N/A	NA
	• Fire Dampers	N/A	N/A	NA
4	Smoke Management System.			
	• Basements	N/A	N/A	NA
	• Upper floors	12 a/c per hour	Mechanical ventilation	MR
5	Fire Extinguishers			
	• Total numbers	Required	Provided	MR
	• Types	ABC & CO ₂ type	ABC & CO ₂ type	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01 nos.	02 Hose Reel Provided at Third Floor	MR
	• Length of hose reel hose	30 m	Provided	MR
7	Automatic fire detection and alarming system. :-			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided at third floor near reception	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA			
9	Public Address System.			
		Required	Provided	MR
10	Automatic Sprinkler System. Not required but provided			
	• Basement	N/A	N/A	NA
	• Entire Restaurant	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided (01)	MR
	• Number of hydrants per floor	01 No.	Provided	MR
	• Hose Box	01 No.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	---	---	---
	➤ Discharge of main Pump	2280 LPM	Provided	MR
	➤ Head of Main pump	60m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	60m	60 m	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 mts	40 mts	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000 Ltrs	Provided in form of steel tanks	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 lts	5000 Ltrs Provided	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts. Lifts not installed			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A


		Required	N-7 Provided	MR
17	Standby power supply			
18	Refuge Area			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note:- The total covered area of restaurant in CAF portal is 655.39 Sq mtr. as per NBC part 4, 2016, sitting capacity comes 364 persons (i.e 655/1.8 = 364.1).

If agreed in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act- 2007 & Rules- 2010.

DFA is put up for approval & signature please.


 Signature of the Inspecting Officer
 Name- Sunil Chaudhary
 Dy. Chief Fire Officer (SZ)


 Signature of the Inspecting Officer
 Name- P.V. Rathee
 Asstt. Div. Officer (S.Rd)

CFO. (D. aff.)

~~Director~~ 13/12/22 H P 11

016/52 letter is put up for signature, please.

~~Director~~ 14/12/22

M56