

C-37

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**

No. F6/DFS/MS/School/WZ/2021/ 101

Dated: 15/12/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Crescent Public School**, Located at **Parwana Road, Saraswati Vihar, Delhi – 110034**, comprised of Basement + Ground + 03 Upper Floors only was issued Fire Safety Certificate by this department Vide Letter No. F6/MS/DFS/School/2018/2551 dated 26.11.2018. The said premises were re-inspected by the officer concerned of this department on 02.12.2021 in the presence of Sh. Sunil Maini (Principal) and found that the premises / buildings have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E Cir. No. 262-362 dated 17-01-2005 and that the premises/building is fit for occupancy "Educational" Group B with effect from 15/12/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/12/2021 at New Delhi by.

80 (Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to: -

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Crescent Public School, Located at Parwana Road, Saraswati Vihar, Delhi – 110034.

**CONDITIONS**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The Basement Shall be used as per BBL.

C-37

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**

No. F6/DFS/MS/School/WZ/2021/ 1011

Dated: 15/12/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Crescent Public School**, Located at **Parwana Road, Saraswati Vihar, Delhi – 110034**, comprised of Basement + Ground + 03 Upper Floors only was issued Fire Safety Certificate by this department Vide Letter No. F6/MS/DFS/School/2018/2551 dated 26.11.2018. The said premises were re-inspected by the officer concerned of this department on 02.12.2021 in the presence of Sh. Sunil Maini (Principal) and found that the premises / buildings have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E Cir. No. 262-362 dated 17-01-2005 and that the premises/building is fit for occupancy "Educational" Group B with effect from 15/12/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/12/2021 at New Delhi by.

82  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to: -

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Crescent Public School, Located at Parwana Road, Saraswati Vihar, Delhi – 110034.

**CONDITIONS**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The Basement Shall be used as per BBL.

## INSPECTION REPORT

1. Name & address of the building: **Crescent Public School Located at Parwana Road, Saraswati Vihar, Delhi-110034.**
2. Type of Occupancy : Educational (Basement + Ground + 3 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/School/2018/2551 dated 26.11.2018
5. Fire Safety directives Letter No. : Circular No- 262-362 Dated-17/01/2005
6. Date of inspection : 02.12.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj. ADO (WP)
8. Name and designation of Officer  
from the building side : Sh. Sunil Maini (Principal)
9. Year of Construction : 1995
10. Applicant's letter No. : email dated 22.11.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.262-362 Dated-17/01/2005/letter dated 26.11.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>Accessible</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>380cm</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR(Old Case)</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtrs	2x155cm	MR
	• Basements	1.5 mtrs	1x320cm&125cm	MR(Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA		NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 mtrs.	2.5 mtrs	MR
	f. Door Size	1 mtr	110 cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	38 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

N/14

7.	Automatic fire detection and alarming system			NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	Required	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	2X450 lpm	Provided	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA

N/15

	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety required under the rules, renewal of Fire safety certificate issued vide letter no. F6/MS/DFS/School/2018/2551 dated-26-11-2018 is recommended under rule 37 of the Delhi Fire Service Rules 2010.

*S.P. Bhardwaj*  
S.P. Bhardwaj, ADO (WP) 3/12/21

~~DO/West~~

D.O. (WEST)/ 292  
DATED... 6/12/2021

~~DO/West~~  
06/12/2021  
*[Signature]*  
10/12/2021

~~DO/West~~

fit report up for bench pm

~~DO/West~~

*[Signature]*  
15/12/2021

*[Signature]*  
18/12/21

rest all