

C-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/WZ/2021/ 1027

Dated: 17/12/2021

FIRE SAFETY CERTIFICATE

Certified that the **Apeejay School**, Located at **Road No-42, Sainik Vihar, Pitampura, Delhi-110034** comprised of Basement + Ground + 03 Upper Floors was issued Fire Safety Certificate vide Letter No. F6/DFS/MS/School/2019/586 dated-22.03.2019. The premises was re-inspected by the officer concerned of this department on 10.12.2021 in the presence of Ms. Veena Goel (Principal) & Sh. Rajeev Kumar (Admin Officer) and found that the building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with BBL/NBC Part-IV and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 17/12/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 17/12/21 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:

1. The Principal, Apeejay School, Located at Road No-42, Sainik Vihar, Pitampura Delhi-110034.
2. The Director, Directorate of Education, GNCT NCT of Delhi, Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The Basement shall be used as per BBL.

14-15

INSPECTION REPORT

1. Name & address of the building: **Apeejay School**, Located at **Road No-42, SainikVihar, Pitampura Delhi-110034.**
2. Type of Occupaney : Educational (Basement + Ground + 03 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2019/586 dated-22.03.2019
5. Fire Safety directives Letter No.:F6/DFS/MS/90/School/1865 dated 23/10/1990
6. Date of inspection : 10.12.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer
from the building side : Ms. Veena Goel (Principal) &
Sh. Rajeev Kumar (Admin Officer)
9. Year of Construction : 2004
10. Applicant's letter No. : email dated 22.11.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Directive/letter dated 22.03.2019	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible 5m NA 	<ul style="list-style-type: none"> 9 m 570 cms NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03	05	MR
	• Basements	04	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 m	3x187cm, 1x2m, 1x198cm & Ramp=145cm	MR
	• Basements	1.5 m	3x187cm & 1x184cm	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided (04)	MR
	e. Width Of Corridor	1.5 m	150 cm	MR
	f. Door Size	100 cm	115cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	25 nos.	40 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	04	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	Required	2x360 LPM	MR(Old Case)
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	1,00,000 ltrs.	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2x25000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

[Handwritten signature]

20. Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA
--	----	----	----

The Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E Cir. 262-362 dated 17-01-2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2019/586 dated-22.03.2019 is recommended.

S.P. Bhardwaj
S.P. Bhardwaj
ADO (WP)

~~DO/West~~

dy
12/12/2021
DO/West
15/12/2021

DO (West)
DATED. 13/12/2021

~~ADO/West~~

It is put up for signature

~~DO/West~~

S.P. Bhardwaj
16/12/21

MS/ cell

R
AR
IR
A
A
R
R
R
N
N
N
N
N
N