

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/School/2021/NDZ/ 1021

Dated: 17/12/21

**FIRE SAFETY CERTIFICATE**

Certified that the E.D.M.C. Pratibha Vidyalaya at Shivpuri (General), Delhi-110051, comprised of ground plus two upper floors owned/occupied by E.D.M.C. Pratibha Vidyalaya, have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 25/11/2021 in the presence of Ms. Ruchi Jain, Incharge & Sh. Kuldeep Kumar Singh, J.E (Electric), Shahdara South Zone the school and that the school building is fit for occupancy class "B" 'Educational Building' with effect from ...17/12/21... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on.....17/12/21..... at New Delhi by

  
(Ajul Garg)  
Director  
of

To,  
The Principal,  
E.D.M.C. Pratibha Vidyalaya,  
Shivpuri (General), Delhi-110051

- Copy:-
1. The Director of Education, EDMC  
419, Udyog Sadan,  
Patparganj Area, Delhi-110092
  2. The Ex. Engr. (Elect.)-II/SSZ  
EDMC, Office of Executive Engineer (Elect.)-II/SSZ,  
2<sup>nd</sup> Floor Technical Laboratory,  
Near Nh-24 Gazipur, Delhi-110096

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

## INSPECTION REPORT


1. Name & address of the building : EDMC Pratibha Vidyalaya, Shivpuri  
(General), Delhi-110051
2. Building is comprised of : Ground plus two upper floors
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 to 3398  
dated- 01/03/2011
7. Date of Inspection : 25/11/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer  
from the building side : Ms. Ruchi Jain, Incharge &  
Sh. Kuldeep Kumar Singh, J.E. (Electric),  
Shahdara South Zone
10. Year of Construction : 2011
11. Applicant's letter no : E.E. (Elect.)-II/Shah(S)/2021-2022/D-570  
dated- 27/10/2021

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	6 m	7 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	2 nos.	2 nos.	MR
	• Basement	N/A	N/A.	N/A
	b. Width of Staircases			
	• Upper Floor	1.5 m/0.75m Add.	1.2 m each	MR(accepted earlier)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	1 no.	1 no.	MR
	e. Width of Corridor	1.5 m	2.8 m	MR
	f. Door Size	01 m	01 m	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers.			
	• Total numbers	6 nos.	6 nos.	MR
	• types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-aid-Hose Reels			
	• Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	Provided	MR
08	MOEFA	N/A	N/A	N/A
09	Public address System	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	➤ Total number of hydrants	N/A	N/A	N/A
	➤ Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	➤ Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the Pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required as per F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/2011 issued by Director of Education, it is recommended to issue Fire Safety Certificate under rule 35 of Delhi Fire Service Rules, 2010.

  
 (Nagender Singh)  
 ADO (Shahdara)

Dy. CFO (NDZ)


  
 7/12/24




CFO (CHD)

  
 9/12




  
 0/12/24

F.T. letter is placed for signature please.

  
 Nagender Singh  
 ADO (Shahdara)

Dy. CFO (NDZ)

  
 15/12/24

Director (SFC)   
 16/12/24