

CS

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No. F.6/DFS/MS/School/2021/NDZ/ 1024

Dated: 17/12/21

**FIRE SAFETY CERTIFICATE**

Certified that the E.D.M.C. Primary School (EnglishMedium)-II at Shri Ram Colony, Rajiv Nagar, Delhi-110094, comprised of ground plus three upper floors owned/occupied by E.D.M.C. Primary School have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 04/12/2021 in the presence of Sh. Pankaj Kumar, Incharge & Sh. Gajender Singh, J.E. (Electric), Shahdara North Zone and that the school building is fit for occupancy class "B" 'Educational Building' with effect from 17/12/21... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on.....17/12/21..... at New Delhi by

  
(Atul Garg)  
Director  
of D.S.

To,  
The Principal,  
E.D.M.C. Primary School (English Medium)-II,  
Shri Ram Colony, Rajiv Nagar,  
Delhi-110094

Copy:-

1. The Director of Education, EDMC  
419, Udyog Sadan,  
Patparganj Area, Delhi-110092
2. The Ex. Engr. (Elect.)-II,  
Shahdara (North) Zone,  
EDMC, Office of Executive Engineer (Elect.)-II,  
MCD Zonal Office Building, Keshav Chowk,  
G.T. Road, Near Shyam Lal College,  
Delhi-110053

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

### INSPECTION REPORT

1. Name & address of the building : EDMC Primary School (English Medium)-II, Shriram Colony Rajiv Nagar, Delhi-110094
2. Building is comprised of : Ground plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No. : NBC Part-IV
7. Date of Inspection : 04/12/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Sh. Pankaj Kumar, Incharge & Sh. Gajender Singh J.E. (Elect.), Shahdara North Zone
10. Year of Construction : 2017-19
11. Applicant's email ID : [eee2shahnorthzone@gmail.com](mailto:eee2shahnorthzone@gmail.com) dated 23/11/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC –IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	6 m	6 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	2 nos.	2 nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.5 m	1.5 m each	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	1 no.	1 no.	MR
	e. Width of Corridor	1.5m	1.74 m	MR
	f. Door Size	1 m	1 m	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers			
	• Total numbers	08 nos.	08 nos.	MR
	• Types	ABC/CO <sub>2</sub>	ABC/CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	1 no. 30 m 05 mm	1 no. 30 m 05 mm	MR MR MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of main panel</li> <li>Location of repeater panel</li> <li>Alternate source of power</li> <li>Hooter</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose box</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby pump out put</li> <li>Standby pump head</li> <li>Auto starting /manual stopping</li> <li>Pump house access</li> </ul>	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	450 LPM 40 m Required Required	450 LPM 40 m Provided Provided	MR MR MR MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead tank capacity</li> </ul>	N/A N/A N/A N/A 10,000 Ltrs.	N/A N/A N/A N/A 10,000 Ltrs.	N/A N/A N/A N/A MR
15	Exit Signage.	Required	Provided	MR

N/3

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required under NBC Part-IV, it is recommended to issue Fire Safety Certificate under rule 35 of Delhi Fire Service Rules, 2010.

*(Signature)*  
 (Nagender Singh)  
 ADO (Shandara)

Dy. CEO (NDZ)

*(Signature)*  
 8/12/21

CFO/CDs

*(Signature)*  
 19/12

*(Signature)*  
 12/12/21  
 And / SAIB

