

C-131

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SZ/Hostel/2021/ 531

Dated: 17/12/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s **International Youth Hostel Building** located at No-5, Nyaya Mage, Chanakyapuri, New Delhi-21, Comprised of Basement, Ground & 3 Upper Floors only owned / occupied by **National Youth Hostel Trust** has already been issued FSC by this office vide letter No. F.6/DFS/MS/SZ/2019/1482 dated 18/07/2019. The premises was re-inspected by the officer concerned of this department on 15/12/2021 in the presence of Sh. J.S Walia (OSD) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building is fit for (Gd. Floor : Reception & Office, 1st Floor : 16 Rooms, 2nd Floor : 19 Rooms, 3rd Floor : 4 Rooms, Total=39 Guest Rooms is fit for occupancy Class "**Residential**" (Group-A) (Hostel Building) with effect from 17/12/2021 for a period of **Five Years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on17/12/21..... at New Delhi



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (S.Z.)

o/c

Copy to: -

1. Authorized Signatory, M/s International Youth Hostel at No-5, Nyaya Mage, Chanakyapuri, New Delhi-21.
2. Addl. C.P. (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110024.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

- N/47
1. Name & address of the building: **M/s International Youth Hostel at No-5, Nyaya Mage, Chanakyapuri, New Delhi-21**
 2. Type of Occupancy : Residential & Lodging, "Ground-A"
 3. Building comprised of : Basement, Ground & 3 Upper Floors
 4. Type of Case : Renewal
 5. Details of previous NOC : F.6/DFS/MS/SZ/2019/1482 dated 18/07/2019
 6. Fire Safety directives Letter No. : NIL
 7. Date of inspection : 15/12/2021
 8. Name of the Inspecting Officer : A.D.O. (S.J.)
 9. Name and designation of Officer from the building side : Sh. J.S Walia (OSD)
 10. Year of Construction : 1976
 11. Applicant's letter received through email ID-ceo@yhaindia.org dated 14/12/2021

**Ground (Rec., Office, Kitchen & Dining Hall), 1st F. (16Room), 2nd F. (19 G.R.) & 3rd Floor (04Room)
Total=39 Guest Rooms**

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12m	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.25 & 1 mtr	1.5 & 1 mtr	MR
	• Basements	1.25 & 1 mtr	1.5 & 1 mtr	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1mtr	1 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 ACPH	Exhaust fan	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	20 Nos	36 Nos	MR
	• Types	ISI marked ABC/W.CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR



6.	First - Aid Hose Reels			
	• Total numbers on each floor	2 Nos	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	Required	150mm	MR
	• Number of hydrants per floor	2 Nos	2 Nos	MR
	• Hose Box	2 Nos	2 Nos	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	Required	Provided	MR
	➤ Head of main pump	1500 LPM	1500 LPM	MR
	➤ Number of main pumps	40m	40m	MR
	➤ Jockey pump out put	1	1	MR
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	35m	35m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	50,000 Ltr	50,000 Ltr	MR
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr	Provided	MR

N/49

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided(DG Set)	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring have also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F.6/DFS/MS/SZ/2019/1482 dated 18/07/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note: Gazette Notification of GNCT/03 Ministry dated 27/5/2019 is not applicable in New Delhi Municipal Committee Area.

[Signature]
16/12/2021

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : A.D.O. (S.J.)

[Signature]
D.O. (S.J.)

[Signature]
Date 16/12/21

[Signature]
DeFO(SJ)

F.T.

[Signature]

[Signature]
D.O. (S.J.)

[Signature]
Date 17/12

[Signature]
D.O. (S.J.)

F.T. is added please.