

C-22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**


No.F.6 DFS/MS/School/2021/SZ/ 1029

Dated: 17/12/2021

**FIRE SAFETY CERTIFICATE**

Certified that **Shahi Public School**, located at 3313, Street No 37, Tughlakabad Extension, New Delhi – 110019 comprised of Basement, Ground plus Two upper floor was issued Fire Safety Certificate by this department vide letter No: F6/MS/DFS/School/2017/SZ/1140 Dated 31-07-2017. The said premise was re-inspected by officer concerned of this department on 10/12/2021 in presence of Mr. Chander Rijhwani (Manager) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class “**Educational Building Group – B**” with effect from 17/12/2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 17/12/2021 at New Delhi by



(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Shahi Public School, located at 3313, Street No 37, Tughlakabad Extension, New Delhi – 110019
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.”

## INSPECTION REPORT

1	Name & Address of the Building	Shahi Public School, 3313, Street No 37, Tughlakabad Extension, New Delhi - 110019		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	<b>Basement, Ground + Two upper floors</b>		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2017/SZ/1140 Dated 31-07-2017		
6	Fire Safety Directives Letter No	DOE Circular 17/01/2005		
7	Date of Inspection	10/12/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Chander Rihwani (Manager)		
10	Year of construction	2005- 2006		
11	Applicant letter No.	Gmail dated 25/11/2021		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1.</b>	<b>Access to Building.</b>			
	• Road width	Required	6 mtr	MR
	• Gate width	NA	4.5 mtr	NA
	• Width of internal road	-NA-	-NA-	-NA-
<b>2.</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	02 Nos	Provided	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	Required	1.20m & 1.28m	MR
	➤ Basement floor	Required	0.93m & 1.05m	MR (old case)
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	02 Provided	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	-NA-	-NA-	-NA-
<b>3.</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	Required	Exhaust fan Provided	MR
	• Upper floors	12 ACPH	NA	NA
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	08 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	01 No	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
<b>7.</b>	<b>Automatic fire detection &amp; alarming system.</b>			






	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2017/SZ/1140 Dated 31-07-2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: Sh. Rajesh Kumar  
 Design: ADO (BCP)

~~DO (SD)~~

~~Signature~~  
14/12/21

~~DCFO(SF)~~

F. d.  
~~Signature~~

~~ADDO (BCP)~~

As approved, F.T. letter is put up for your signature pl

~~Signature~~

~~Signature~~  
17/12

14/12  
16/12

M-S. cell