

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2021/NDZ/ 984

Dated: 06/12/2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Deenbandhu Primary School located at J-169-174, Seemapuri, Delhi-110095, comprised of ground plus one upper floor owned/occupied by M/s Deenbandhu Primary School was issued FSC vide letter No. F.6/DFS/MS/2015/NDZ/870 dated 28/05/15. The school building was re-inspected by the officer concerned of this department in presence of Mrs. Treeza (Teacher) of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that school building is fit for ground plus one upper floor occupancy class "B" 'Educational Building' with effect from 06/12/2021 for a period of **three** years, subject to conditions, printed below.

Issued on 06/12/2021 at New Delhi by

  
3/12/21

(Dr S.K Tomar)  
Dy. Chief Fire Officer

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

To,

The Head Mistress,  
M/s Deenbandhu Primary School located at J-169-174, Seemapuri, Delhi-110095

Copy:

The Dy. Director of Education,  
B-Block, Yamuna Vihar, Delhi-110053

- N/7
1. Name & address of the building : Deenbandhu Primary School,  
J-169-174, Seemapuri, Delhi-110095
  2. Building is comprised of : Ground plus first floor only
  3. Type of Occupancy : Educational
  4. Type of Case : Renewal
  5. Details of Previous NOC letter : F.6/DFS/MS/2015/NDZ/870 Dated-28/05/15
  6. Fire Safety direction letter No : Dir. of Edu. Circular Letter No.262-362 Dated-17/01/05
  7. Date of Inspection : 22/11/2021
  8. Name of the Inspecting officer : ADO Mehmood
  9. Name and designation of officer  
from the building side : Mrs. Treeza(teacher)
  10. Year of Construction : 1980-81
  11. Applicant's letter No : Letter No.-Nil, Dated- 22/11/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 mtr. N/A N/A	06 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	01 Nos. N/A	02 Nos. N/A.	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	1.50 mtr. N/A	0.75 mtr. each N/A	MR N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	01 Nos.	01 Nos.	MR
	e. Width of Corridor	1.50 mtr.	0.55 mtr (old accepted)	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• types</li> <li>• IS marking</li> </ul>	04 nos. ABC /CO <sub>2</sub> ISI marked	05 nos. ABC /CO <sub>2</sub> ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	6.5 mm	6.5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	220 Lpm.	220 Lpm.	MR
	➤ Head of the pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 Ltrs.	2500 Ltrs.	MR
15	Exit Signage.			
		N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

D. K. \* Des.

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular No. 262-362 dated 17/01/2005, it is recommended to renewal Fire Safety Certificate under rule 35 of Delhi Fire Service rule 2010.

*Mehmood*  
29/11/2021

Signature of the Inspecting Officer  
Name - Mehmood  
Designation - A.D.O(T.P)

Dy. CFO(NDZ)

*Mehmood*  
30/11/21



A.D.O (T.P)

*for* of B-7 delhi put up for inspection.

*Deputy CFO*

*Mehmood*  
31/12/21

*Mehmood*  
2/12/2021  
A.D.O (T.P)