

C-28

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2021/SZ/ 1031

Dated: 20 / 12 / 2021

FIRE SAFETY CERTIFICATE

Certified that the St. Martin's Diocesan School located at Church Road, Delhi Cantt, New Delhi – 110010, comprised of Ground Floor only owned / occupied by St. Martin's Memorial Educational & Welfare Society Regd., was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/927 dated 04/05/2018. The premises was re-inspected by the officer concerned of Fire Service on 10/12/2021 in the presence of Smt. K. Sudha (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the circular issued by the Director of Education dated 17/01/2005 and that the building is fit for occupancy class "Educational" (Group-B) with effect from 20 / 12 / 2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 20 / 12 / 2021 at New Delhi by



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.)

Copy to :-

o/c Alta


1. The Principal, St. Martin's Diocesan School, Church Road, Delhi Cantt, New Delhi – 110010.
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

4/12
INSPECTION REPORT

1. Name & address of the building: St. Martin's Diocesan School, Church Road, Delhi Cantt, New Delhi – 110010.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground Floor only
4. Type of Case : Renewal
5. Details of previous NOC No. : F6/DFS/MS/School/2018/SZ/927 dated 04/05/2018
6. Fire Safety directives Letter No. : DOE Cir. 262-362 dated 17/01/2005
7. Date of inspection : 10/12/2021
8. Name of the Inspecting Officer : A.D.O. (S.J.)
9. Name and designation of Officer from the building side : Smt. K. Sudha (Principal)
10. Year of Construction : 1960
11. Applicant's letter No. : Nil outdoor diary no. 4923 dated 03/12/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NM/R
1.	Access of building			
	• Road width	Required	9 m	MR
	• Gate width	Required	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	NA	NA	NA
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	1m	1m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	Required	20	MR
	• Types	ABC /WC ₂	ABC & Co2	MR
	• ISI marking	ISI Marked 	ISI Marked	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

[Handwritten signature]

4-14

15	Exit Signage	NR	NR	NR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2018/SZ/927 dated 04/05/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

[Signature]
20/12/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

~~DO(SD)~~ *[Signature]*
19/12/21 F.T.

~~DCFO(S2)~~ *[Signature]*

~~ADU(S.J)~~
F.T. is added pl.

~~DYCF0(S2)~~ *[Signature]*
20/12/2021
M.S. Cell