

E-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/SZ/ 384

Dated: 29/12/2021

FIRE SAFETY CERTIFICATE

Certified that M/s **Andreas Bistro** (A unit of Eatinc Food and Beverages Pvt. Ltd) located at Property No. 307, **Second Floor**, DLF Promenade Mall, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070 in a building comprised of Two Tiers Basement, Lower Ground, Upper Ground floor and First Floor & Projection room owned/ occupied by Mr. Andrea Aftab Pauro have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 15/04/2021 in the presence of Mr. Prashant Khurana and that the premise is fit for occupancy class **Group-D Assembly Building (Restaurant running at Second floor only)** with effect from 29/12/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/12/2021 at New Delhi by

(ATUL GARG)
 DIRECTOR / DFS

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID 2021102625125 dated 19/11/2021)
3. M/s Andreas Bistro (A unit of Eatinc Food and Beverages Pvt. Ltd) Situated at Pro. 307 Second Floor, DLF Promenade Mall, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Andreas Bistro (A unit of Eating Food and Beverages Pvt. Ltd) Situated at Pro. 307 Second Floor , DLF Promenade Mall, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Two tier Basement, LGF, UGF, 1 st Floor + Projection		
4	Type of Case	New case / Old name Namak Mandi		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	UBBL-2016		
7	Date of Inspection	14/12/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Prashant Khurana		
10	Year of construction	2005	Restaurant running at 2 nd Floor in DLF Promenade Mall building.	
11	Applicant letter No.	MHA Portal ID 2021102625125 dated 19/11/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement/ Existing Fire Protection	Provided at Site	Remarks MR/NMR
1	Access to Building. FSC No.F.6/DFS/MS/Mall/2020/SZ/58 Dated 22/01/2020 of DLF Promenade Mall			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restaurant within Mall	As above As above As above	MR N/A N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	02 Nos N/A	As above As above	MR N/A
	b. Width of Staircase	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	Required N/A	As above As above	MR N/A
	c. Protection of exits	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	As above As above	MR N/A
	d. No. of continuous staircase to terrace	Required	As above	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	02 Exits 1.50 mtr each	1.50 m & 1.50 m	MR
3	Compartmentation.	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	Required N/A N/A N/A N/A	As above As above N/A N/A N/A	MR N/A N/A N/A N/A
4.	Smoke Management system.	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Basement • Upper floors 	N/A Required	As above Exhaust fans provided	N/A MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	06 Nos ISI marked	06 Nos. ABC-04, W.CO ₂ -02 Provided	MR MR MR
6.	First Aid Hose Reels.	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	Hose Reel	One in Restaurant 30m 5mm	MR MR MR

7	Automatic Fire Detection and Alarming system. (Provided & Maintained by DLF Promenade Mall			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's location 	Required	Smoke & Heat	MR
		Required	As above	MR
		N/A	N/A	N/A
		Required	As above	MR
		Required	As above	MR
8.	MOEFA	Required	As above	MR
9.	Public Address System	Required	As above	MR
10.	Automatic Sprinkler System	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Basement • Upper floors • Sprinkler above false ceiling 	Required	As above	MR
		Required	Provided in Restt.	MR
		N/A	N/A	N/A
11.	Internal Hydrants.	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Size of Riser/Down-comer • Number of Hydrant per floor • Hose box. 	Required	As above	MR
		Required	As above	MR
		Required	As above	MR
12.	Yard Hydrants.	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Total number of hydrants. • 2. Hose box. 	N/A	As above	N/A
		N/A	As above	N/A
13.	Pumping arrangements.	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Ground Level 	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting / Manual Stopping. ➤ Access to pump house 	4500 LPM	As above	MR
		70 mtrs	As above	MR
		Two	As above	MR
		450 LPM	As above	MR
		70 mtrs	As above	MR
		4500 LPM	As above	MR
		70 mtrs	As above	MR
		Required	As above	MR
		Required	As above	MR
		<ul style="list-style-type: none"> • Terrace Level 	Provided & Maintained by DLF Promenade Mall	
	<ul style="list-style-type: none"> ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. • Overhead tank capacity. 	5,00,000 Ltrs	As above	MR
		Required	As above	MR
		Required	As above	MR
		Required	As above	MR
		20,000 Ltrs	As above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room.	Provided & Maintained by DLF Promenade Mall		
	<ul style="list-style-type: none"> • Detector System Panel. 	N/A	As above	N/A

	• Flow Switch Panel.	N/A	As above	N/A
	• PA system Panel.	N/A	As above	N/A
	• Battery backup	N/A	As above	N/A
	• Building floor plan	N/A	As above	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	As above	N/A

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 934 dated 30/12/2020 for the name of M/s Namak Mandi Restaurant.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.

[Handwritten Signature]
16/12

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

~~DO (SD)~~

[Handwritten Signature]
16/12

~~DeFO (S2)~~

[Handwritten Signature]
29/12

~~CP/O~~

[Handwritten Signature]
27/12

~~of [Handwritten Signature]~~
22/12/2020

~~ADP/ADP~~

[Handwritten Signature]
28/12/2021

As approved, F-7 letter is
put up for your signature pl
1/19
28/12



uploaded MHA online portal
27/12/2021