

C-26

7.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 1066


Dated: 24/12/2021

FIRE SAFETY CERTIFICATE

Certified that **Defence Foundation Public School** located at **B-22, Laxmi Park, Nangloi, New Delhi- 110041**, comprised of ground and first floor only, owned/occupied by Dharam Foundation Education Society (Regd.), was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2017/WZ/471 dated 296.03.2017. The school building was re-inspected by the officer concerned of this department on 20.12.2021, in the presence of Sh. Vikas Shokeen, manager of the School and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular no. 262-362 dated 17.01.2005 and that the building/premises is fit for occupancy class "Educational" with effect from 24/12/2021 for a period of three years, subject to compliance of the conditions, printed overleaf.

Issued on 24/12/2021 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)


24/12/2021
d/c
22/12/21

Copy to: -

1. The Principal, Defence Foundation Public School, B-22, Laxmi Park, Nangloi, New Delhi- 110041.
2. The Directorate of Education, GNCT of Delhi, Old Secretariat, Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.
9. Two rooms constructed on 2nd floor are sealed with brick wall by school management. If these rooms found using for any purpose, this FSC shall be treated at Null & Void.

INSPECTION REPORT

1. Name & address of the building : Defence Foundation Public School, B-22, Laxmi Park, Nangloi, New Delhi- 110041.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/WZ/471 dated 29/03/2017
5. Fire Safety directives letter No : Directorate of Education Cir. No. 262-362 dt. 17.01.2005
6. Date of inspection : 20.12.2021
7. Name of the Inspecting Officers : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of officers
from the building side : Sh. Vikas Shokeen, Manager
9. Year of Construction : 2005
10. Applicant's letter No. : E-mail dated 07.12.2021

The School building is comprised of ground and first floor only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per DoE cir. Dt. 17.01.2005	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt.	1.38, 0.75 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.0 mts	1.0 mts	MR
	h. Door Size	1.0 mt	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilation provided	MR

5	Fire Extinguishers				
	<ul style="list-style-type: none">Total numbersTypesIS marking	06 nos. ABC, CO ₂ type ISI marked	Provided Provided Provided	MR MR MR	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none">Total numbers on each floorLength of hose reel hoseNozzle diameter	01 30 mts 5 mm	Provided Provided Provided	MR MR MR	
7	Automatic fire detection and alarming system				
	<ul style="list-style-type: none">Type of detectorsLocation of Main PanelLocation of Repeater PanelAlternate source of powerHooters' Location	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	
8	MOEFA	N/A	N/A		
9	Public Address System.	N/A	Provided	----	
10	Automatic Sprinkler System				
	<ul style="list-style-type: none">BasementUpper FloorSprinkler above false ceiling	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A	
11	Internal Hydrants				
	<ul style="list-style-type: none">Size of riser/down-comerNumber of hydrants per floorHose Box	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A	
12	Yard Hydrants.				
	<ul style="list-style-type: none">Total number of hydrantsHose Box	N/A N/A	N/A N/A	N/A N/A	
13	Pumping Arrangements				
	<ul style="list-style-type: none">Ground Level<ul style="list-style-type: none">Discharge of main PumpHead of Main pumpNumber of main pumpsJockey Pump out putJockey pump headStandby Pump out putStandby Pump HeadAuto Starting/ Manual stoppingPump House AccessTerrace level<ul style="list-style-type: none">Discharge of pumpHead of the pumpPower SupplyAuto Starting of pump	--- N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A ---- 220 LPM 40 mts Required Required	----- N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A ----- Provided Provided Provided Provided	----- N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A ----- MR MR MR MR	
14	Captive Water Storage for fire fighting				
	<ul style="list-style-type: none">Underground tank capacityDraw-off connectionFire service inletAccess to tankOverhead Tank capacity	N/A N/A N/A N/A 2500 lts	N/A N/A N/A N/A Provided Provided	N/A N/A N/A N/A MR MR	
15	Exit Signage.	Required	Provided		

16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: - Two Rooms constructed on 2nd floor are sealed with brick wall by school management. If these rooms found using for any purpose, this FSC shall be treated as Null & Void.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2017/WZ/471 dated 29/03/2017, renewal under circular of DoE No. 262-362 dated 17.01.2005, is recommended.

DFA is put up for approval & signature please.

D.O. (WEST) 208
DATED 20/12/2021

(Signature)
20/12/21

Signature of the Inspecting Officer
(Aman Kumar Lathar)
Asst. Divisional Officer (JWP)

D.O. (West Division)

DFO (WZ)

(Signature)
20/12/2021

AAO JWP

F.S. letter is put-up for your signature pl.
(Signature) 21/12/2021
(Signature) 24/12/2021
(Signature) 22/12/2021
Asst Insp!

msf cell